Efficient Energy Management in Smart Micro-Grids: ZERO Grid Impact Buildings

Pablo Arboleya, Senior Member, IEEE, Cristina Gonzalez-Moran, Member, IEEE, Manuel Coto, Member, IEEE, Maria Carmen Falvo, Senior Member, IEEE, Luigi Martirano, Senior Member, IEEE, Danilo Sbordone, Ilaria Bertini, and Biagio Di Pietra

Abstract-In a smart micro-grid (MG) each generator or load has to take part in the network management, joining in reactive power supply/voltage control, active power supply/frequency control, fault ride-through capability, and power quality control. This paper includes a new concept for building integration in MGs with zero grid-impact so improving the MG efficiency. These aims are shown to be achievable with an intelligent system, based on a dc/ac converter connected to the building point of coupling with the main grid. This system can provide active and reactive power services also including a dc link where storage, generation, and loads can be installed. The system employed for validation is a prototype available at ENEA Laboratories (Italian National Agency for New Technologies). A complete and versatile model in MATLAB/SIMULINK is also presented. The simulations results and the experimental test validation are included. The trial confirms the model goodness and the system usefulness in MG applications.

Index Terms—Dispersed generation (DG), electrical energy distribution, energy storage, green buildings, simulation, smart micro-grids (MGs), steady-state modeling.

NOMENCLATURE

Acronyms	
BMS	Battery management system.
CHP	Combined heat and power.
CPD	Custom power device.
DG	Dispersed generation.
DSO	Distribution system operator.
DSTATCOM	Distribution static synchronous compensator
ENEA	Italian National Agency for New
	Technologies Energy and Sustainable
	Economic Development.
LV	Low voltage.
MG	Microgrid.
MPPT	Maximum power point tracking.
MV	Medium voltage.

Manuscript received February 11, 2014; accepted December 16, 2014. This work was supported by the Spanish Ministry of Science and Innovation under Grant ENE2013-44245-R (MICROHOLO Development of a Holistic and Systematical Approach to AC Microgrids Design and Management). Paper no. TSG-00093-2014.

P. Arboleya, C. Gonzalez-Moran, and M. Coto are with the Department of Electrical Engineering, University of Oviedo, Gijón 33204, Spain (e-mail: arboleyapablo@uniovi.es).

M. C. Falvo, L. Martirano, and D. Sbordone are with the Department of Electrical Engineering, University of Rome Sapienza, Rome 00184, Italy.

I. Bertini and B. Di Pietra are with the Italian National Agency for New Technologies (ENEA), Rome 00123, Italy.

Digital Object Identifier 10.1109/TSG.2015.2392071

NZEB	Nearly zero-energy building.
PC	Point of coupling.
PHEV	Plug-in hybrid electrical vehicles.
PI	Proportional-integral.
PLL	Phase locked loop.
SD	Switching device.
TSO	Transmision system operator.

Subscripts

Synchronous reference frame components
Droop slope.
Integral.
Measurement.
Active power control gain.
Proportional.
Reactive power control gain.
Reference.
Switching device number 1.

SD2 Switching device number 2.

Superscripts

A Building coupling with the grid.

- *B* Main dc/ac converter coupling with the building.
- AC Grid.
- *C* Main dc/ac converter output.
- D DC bus.
- Li-Po Output of the lithium-polymer battery.
- max Maximum allowed value.
- PV Output of the photovoltaic module.

Variables

- *I* Current.
- *k* Droop slope or proportional or integral gain.
- *P* Active power.
- *Q* Reactive power.
- U Voltage.

I. INTRODUCTION

I N RECENT years, many changes have occurred in the electricity sector to improve the energy efficiency and environmental sustainability of generation, transport and final use segments, involving the need to update and improve the electric grids [1]–[3]. The first revolution deals with the deregulation of the electrical industry, by means of the markets

1949-3053 © 2015 IEEE. Personal use is permitted, but republication/redistribution requires IEEE permission. See http://www.ieee.org/publications_standards/publications/rights/index.html for more information.

1

IEEE TRANSACTIONS ON SMART GRID

introduction: the electricity service has been opened to the generation plants owners and also to the final users; this has influenced the operational functions initially belonging to TSO and DSO [4]-[6]. Another important change regards the spread of the so-said dispersed or distributed generation (DG), including renewable sources generation plants (such as PV or wind micro-turbine) and high efficiency production systems (such as gas micro-turbine or CHP) [7]. The DG has had a big impact on transmission and distribution grids, in terms of electricity flows and protection systems. The promotion of NZEBs construction constitutes another important innovation in the electric grid [8]. NZEB means a building that has a very high energy performance being the low amount of energy required covered to a significant extent by energy from renewable sources and CHP, both for residential and commercial buildings.

In traditional power systems, the reliability impact could be significant when a large amount of variable DG is integrated on it. It is well known that the chaotic phenomena in the existing distribution grids will occur when the DG penetration reach a high level compared to the net energy, causing network congestion and so compromising the energy quality by voltage and frequency disturbances.

For all the above mentioned reasons, the uncertainties associated to markets, DG and PHEVs have to be taken into consideration by the new systems, making possible real interactions between generators, users, and grid. The new systems must be implemented to transform the traditional electrical grid into a flexible, open-access, and sustainable system, called smart grid [9]. The European Union provides this definition: A smart grid is an electricity network that can intelligently integrate the actions of all users connected to it -generators, consumers and those that do both- in order to efficiently deliver sustainable, economic, and secure electricity supplies. In other words, the evolution of distribution grids through smart grids is calling for similar actions adapted to the transmission grids.

At the same time, another concept related to the distribution grid has been proliferating: the MG concept. A MG is a small electricity network, generally in LV level, connected to other MGs and/or to the main grid (generally in medium voltage, using a single point of connection (PC). A MG generally includes DG, electrical loads of different types (i.e., PHEVs) and energy storage devices in a reduced space. In a MG, each actor could take part into: reactive power supply and voltage control; active power supply and frequency control; and fault ride-through capability and power quality control (flicker, harmonics) [10].

This paper presents a new concept for buildings integration in smart grids. The proposed system integrates in the same building ac and dc distribution. The two distribution systems are coordinated and connected through a dc/ac converter. the whole system can provide active and reactive power to the building and/or to the main grid among other ancillary services as a reactive compensation functions. The whole building will work as a two coordinated small MG or as a dispatchable load or generator.

The rest of this paper is organized as follows. In Section II, the electrical system of the building will be described. Also an

overview on the main function that a CPD with energy storage can perform in the MG management is included. In Section III, the control of all the system parts is explained. Section IV summarizes the simulation results carried out in MATLAB/SIMULINK. In Section V, the real prototype that has been used to test the system in a real smart MG, available at ENEA Laboratories is described and the obtained measurements during a case study are discussed. Section VI presents the conclusion about the use of CPDs.

II. SYSTEM DESCRIPTION

In Fig. 1, the general scheme of the proposed CPD installed at one of the ENEA buildings is depicted. As it can be observed the system has two different parts; the first one is the ac subsystem that is connected to the main grid and to the building loads. The second part is the dc subsystem where the energy storage system based on Li-Po batteries is installed. In the dc side there are also dc loads, a voltage limiter resistor (VLR) for over-voltage protection and a PV generator (PV module). This last element is not installed in the real prototype yet, however, it is included in simulations to study the effect of such generation over the whole system. In Fig. 2, a photograph of the real prototype is shown.

In the next subsections the different elements that compose the CPD will be described.

A. Li-Po Batteries

The energy storage system is based on Li-Po batteries. The whole module is constituted by 280 cells connected in series with a rated energy storage of 70 Wh per cell. The total pack capacity is 16 kWh. The system is able to discharge at a maximum rate of 20 kW in 15 min or 10 kW in an hour. The ratio between the maximum output power and the rated energy is 4-8 h⁻¹. The maximum operating temperature is 45 °C at a relative humidity range of 40%–90%. The estimated life is about 2000 cycles at 80% discharge. The batteries pack rated voltage is 270 V at full charge. However, the pack is split into several sections with voltages not greater than 60 V. As it can be observed in Fig. 2, the batteries location facilitates the manual access to all accumulator terminals.

The battery pack is connected to the 600 V dc bus using a bidirectional dc–dc Buck-Boost converter whose topology can be observed in Fig. 3(a). The BMS controls the converter trying to keep a constant voltage in the dc bus but limiting the charge and discharge rate to ensure the correct operation of the battery pack. A detailed explanation of this control will be given in the next section. The BMS acquires the cells voltage, current, and temperature so it also estimates the storage system state of charge.

The dc bus over-voltage protection is also ensured by a 60 Ω VLR of 60 Ω connected by means of a chopper. The scheme of this protection is depicted in Fig. 3(c) and its control will be also described in the next section.

B. Main AC–DC Converter

The power converter has been built using solid state static components; it is equipped with IGBTs. The switching



Fig. 1. General scheme of the CPD.



Fig. 2. Real prototype installed at ENEA laboratory.

over-voltages must not exceed 200 V at full power. For this purpose special limiting circuits are included. IGBTs are also equipped with detection circuit desaturation. The detection saturation has been locally done with a hardware circuit connected to the anode of each transistor and must lead to the immediate arrest of its conduction. At the same time a blocking signal should be sent, via the logic control, to arrest of the whole converter. The overheating protection of the device is implemented with temperature sensors inside the semiconductor module. The static converter is provided with appropriate input and output filters for suppressing disturbances, according to the directives 89/336/EEC and 92/31/EEC. The connection to the 400 V ac grid is complied with the requirements of the Italian Standard CEI 0-21. The 600 V dc bus-bar is sized to connect both a dc load with a maximum power of 20 kW and a production system with a maximum power of 30 kW.

A detection and protection system provides the information about the components status: power supply for the electronics out of range, communication error with Digital Signal Processor, bar voltage out of range, inverter over-temperature, leakage currents to ground, gear time out, inverter overcurrent, protection IGBT modules, thermal protection inverter, line voltage out of range, and low line voltage alarm.

The control of the main converter will be deeply described in the next section.

C. Loads

The loads are placed at the ac side and at the dc side of the main converter. In the ac side the load is the ENEA building consumption, that can oscillate between 36 and 228 kW. In the dc side, the loads are composed by some auxiliary dc loads being the most important the system ventilation. The total amount of dc load is about 5 kW.

III. SYSTEM CONTROL DESCRIPTION

In this section all the system controls and the interaction between them will be described. In Fig. 1, a general overview of the system was presented, and as it was previously stated, the only difference between the modelled system and the real prototype is the PV generator connected to the dc side.

As it can be observed in Fig. 1, there are basically four points of measurement for voltages and currents, (A, B, C, and D). The voltages and currents at the PC (point A) are measured to calculate the power that the building injects or demands from the network. Measurements at B are used to control the transferred power from the dc to the ac side of the system or vice versa. The currents at C are also needed to



Fig. 3. Converter topologies used in the dc subsystem. (a) Bidirectional dc-dc Buck-Boost converter that connects the Li-Po battery with the dc bus. (b) Unidirectional dc-dc Buck-Boost converter that connects the PV module with the dc bus. (c) Chopper for activating the VLR.



Fig. 4. Control of the dc/ac main converter.

implement the current control of the main converter. Finally, the dc bus voltage will be acquired at D.

The magnitudes needed at each device control will be enumerated in the next subsections.

A. Main Converter Control

In Fig. 4, the basic control system of the ac/dc main converter can be observed. It is basically a PQ control over an inner current loop control.

The active and reactive power references are calculated as follows:

$$P_{\rm ref}^B = \left(k_{p,P} + \frac{k_{i,P}}{s}\right) \cdot \left(P_{\rm meas}^A - P_{\rm ref}^A\right) \tag{1}$$

$$Q_{\text{ref}}^{B} = Q_{0}^{B} - k_{\text{droop},Q} \cdot \left(U_{d,\text{meas}}^{B} - U_{d,0} \right).$$
(2)

The measured active and reactive powers at A are considered positive if the building is consuming. Thus, if the power that the building is demanding is greater than the reference at A set by the building management system, the active power reference of the main converter (at B) will be increased. The configuration of the proportional and integral gains of this control ($k_{p_g,ac}$ and $k_{i,ac}$), is critical because when a fast response is desired the dc bus voltage could become unstable, so a properly coordination between this control and the battery control must be assured.

Regarding the reactive power a droop control is implemented (2). If the PC voltage is equal to the rated voltage $(U_{d,0})$ no reactive power is injected to the ac side. If the measured voltage is lower than the rated, the main converter will inject a reactive power proportional to the difference between the rated and the measured powers. The proportionality constant will be the slope $k_{\text{droop},Q}$. $U_{d,0}^B$ and Q_0^B are the rated voltage and the injected reactive power at rated voltage that is set to zero in a general case. These three parameters $k_{droop,Q}$, $U_{d,0}^{B}$, and Q_{0}^{B} are implicit in the droop equation (2), represented also in the droop block in Fig. 4. The opposite behavior is obtained when the measured voltage is greater than the rated. Using this control not only the active power that is exchanged with the grid is controlled, but also a reactive power supporting to the main grid is assured. If the reactive power support is not needed the control can be deactivated giving zero value to the reactive power reference. Another possibility could be the use of a reactive power control similar to the one described for the active power, allowing the system to work with a fixed power factor.

Once the active and reactive power references are set (Fig. 4), the current references are calculated. In this case, a PLL is configured to straighten the d, q references with the measured voltage so this means that $(U_{q,\text{meas}}^B = 0)$ and the current references can be calculated as follows:

$$I_{d,\text{ref}}^C = \frac{P_{\text{ref}}^B}{1.5 \cdot U_{d,\text{meas}}^B} \tag{3}$$

$$I_{q,\text{ref}}^C = \frac{-Q_{\text{ref}}^B}{1.5 \cdot U_{d,\text{meas}}^B}.$$
(4)

An overcurrent protection and a dc bus voltage protection are also implemented, limiting the active power reference when the dc bus voltage drops below a preset value.

B. Li-Po Battery Control

The Li-Po battery is connected to the dc bus by means of a bidirectional dc/dc Buck—Boost converter as it is depicted in Fig. 3(a). In this case, the voltage polarity is inverted. To control the charge/discharge of the battery, the voltage and current at point D (dc bus) are needed, but also the voltage and current at the battery terminals labeled in this case as (Li-Po).

The power flow is controlled by the duty cycles $(D_{\text{SD1}}^{\text{Li-Po}})$ and $D_{\text{SD2}}^{\text{Li-Po}}$ of the IGBT SDs labeled as $SD_1^{\text{Li-Po}}$, and $SD_2^{\text{Li-Po}}$. The SDs are not fired at the same time. When the discharge

The SDs are not fired at the same time. When the discharge of the battery is required, SD_1^{Li-Po} is controlled and SD_2^{Li-Po} duty cycle is set to zero. On the other side, if the battery has to be charged, the control actuates over SD_2^{Li-Po} duty, switching SD_1^{Li-Po} off.



Fig. 5. Control of dc/dc converters. (a) Li-Po dc/dc converter control. (b) PV dc/dc converter control. (c) VLR chopper control.

In Fig. 5(a), $SD_1^{\text{Li-Po}}$ and $SD_2^{\text{Li-Po}}$ controls are represented. To determine if the power reference $P_{\text{ref}}^{\text{Li-Po}}$ is positive or negative the measured dc bus voltage U_{meas}^D is subtracted from the reference U_{ref}^D and the error is conducted through a PI. The PI output is the power reference $P_{\text{ref}}^{\text{Li-Po}}$. If it is positive, the battery must be discharged to increase the dc bus voltage. Then, the power reference $P_{\text{ref}}^{\text{Li-Po}}$ is compared with the measured value $P_{\text{meas}}^{\text{Li-Po}}$ and if the reference is higher, $SD_1^{\text{Li-Po}}$ duty $(D_{\text{SD1}}^{\text{Li-Po}})$ will be increased in steps of 0.1. The battery protection system will limit the power reference as well as the current and voltage. As long as the power reference is positive, $SD_2^{\text{Li-Po}}$ duty will be set to zero.

If the power reference is negative, the battery must be charged. Again, if the measured rate of charge is lower than the reference, $SD_2^{\text{Li-Po}}$ duty will be increased in steps of 0.1, on contrary the duty will be reduced. While the battery is charging $SD_1^{\text{Li-Po}}$ duty is set to zero.

With the described method there is no need of communication between the main converter and battery controls because the former transfers the active power necessary to control the building net power and the latter will keep stable the dc bus voltage.

C. PV Module Control

The PV module is connected to the dc bus through an unidirectional dc/dc Buck–Boost converter. In Fig. 3(b), the topology of this converter is presented. If the converter is compared with the bidirectional one used in the battery, the only difference is that the second SD has been replaced by a diode.

In this case, the control system just actuates over the SD_1^{PV} duty cycle. To calculate the duty, a MPPT algorithm is used to extract the maximum available power at the PV module. The MPPT inputs are the PV module terminals voltage and current (U_{meas}^{PV} and I_{meas}^{PV}). The output is the PV terminals voltage reference necessary to extract the maximum power U_{ref}^{PV} .

The system works at the point in which the derivative of the voltage with respect to power is zero. If dP/dU > 0 the voltage must be increased and if dP/dU < 0 the voltage must be decreased.

If the reference voltage is higher than the measured value, SD_1^{PV} duty will be reduced, otherwise it will be increased. An scheme of the control system is depicted in Fig. 5(b). Anyway, with this topology the power always flows from the PV module to the dc bus. A detailed description of the PV model and the MPPT algorithm can be found in [11].

D. VRL Control

The voltage resistor limiter is activated through a chopper such as the one in Fig. 3(c). As it can be observed in Fig. 5(c). When the measured dc voltage U_{meas}^D is greater than a preset maximum value U_{max}^D , the SD_1^{VLR} duty is increased in steps of 0.1. As it is going to be analyzed in the next section, the battery rate of charge is limited for security reasons. As a consequence, to reduce the dc voltage when the load is suddenly reduced, part of the energy must be burned in the VRL. This system is designed to assist the battery to control the transient dc bus voltage rises. However, if the system is properly sized and designed, it should not work during the steady state condition.

IV. ANALYSIS OF THE SYSTEM BEHAVIOR

A MATLAB/SIMULINK model of the proposed system was implemented in order to test the controls. The model will be later validated with the real prototype. The only difference between the model and the prototype is that the model also includes a PV generator.

The PV generator is modelled as a 34 modules connected in series. Each module is formed by 60 series cells of 218 W_p . The model parameters were obtained from the SLK60P6L module sheet of characteristics, manufactured by SILIKEN. The mathematical model is the so called single diode five parameters. Further details about its implementation in MATLAB/SIMULINK can be found in [11].

Both the ac and the dc loads are considered as constant impedance. For this reason, in the simulation results it can be seen that a change in the dc voltage or grid voltage will provoke a change in the power absorbed by the dc load or the ac load, respectively. The ac load has been modelled as two parallel RL loads being the first one(load 1): $R = 50 \Omega$ and $X = 50 \Omega$, and the second one (load 2): $R = 100 \Omega$ and $X = 100 \Omega$. Both of them can be connected or disconnected using loads 1 or 2 breakers. The dc load is modeled as a resistor $R = 60 \Omega$ and can be also connected or disconnected using the dc load breaker.

In Fig. 6, a case study is analysed. The simulation time is 3 s in which 10 different events occur. During the simulation, U_{ref}^D is set to 600 V and the maximum dc voltage U_{max}^D is 620 V. The maximum voltage has been chosen to illustrate the system behavior when it is reached.

In t = 0 the system is activated with a P_{ref}^B set to zero, load 1 breaker is closed and load 2 breaker is opened. Since the voltage at the ac subsystem is equal to its rated value (400 V),



Fig. 6. Case study. (a) Active power at the ac part of the system (kW). (b) Reactive power at the ac part of the system (kVA). (c) Active power at the dc part of the system (kW). (d) DC bus voltage (V). (e) Current at point A (See Fig. 1), during the study interval. ABC injected in the ac system by the main converter (at point B).

the load 1 will absorb 3.2 kW and 3.2 kVA. At the beginning, part of the power is extracted from the grid because the speed of response of the main converter is limited to preserve the dc bus voltage stability. That is why up to 2.5 kW are absorbed from the grid at the first time instants, but before t_1 is reached the main converter provides the required 3.2 kW, and the active power from the grid becomes zero [see Fig. 6(a)]. Since the voltage in the ac subsystem is equal to its rated value, no reactive power will be injected/absorbed by the main converter due to droop control, being the reactive power required by the ac load (3.2 kVA) obtained from the grid [see Fig. 6(b)].

In the dc bus, the PV module is working with fixed irradiation at 1000 W/m² and temperature at 298 K. Under these conditions, the PV module is injecting 6.4 kW to the dc bus. The rated dc load is 6 kW, however, the voltage is about 595 V, so the dc load will absorb 5.9 kW. In the dc bus there is an extra generation of 0.5 kW and $P_{\text{ref}}^{\text{B}}$ is still set to zero, so the main converter has to transfer 3.2 kW from the dc part to the ac part, for this reason 2.7 kW must be extracted from the battery. The battery power reference rate of change is limited and during the first instants, so power provided by the battery is lower than 2.7 kW [see Fig. 6(c)], and because of this unbalance between power injection and demanded power in the dc bus, the voltage is lower than 600 V [see Fig. 6(d)].

At $t_1 = 0.3 s$, before the steady state is reached, the dc load breaker is opened, at this time the rate of discharge of the battery is approximately 3 kW and the PV module is injecting 6.4 kW, the power reference is not changed at the main converter, so the dc part has to provide the 3.2 kW demanded by the ac load. The net balance between generation and load at the dc bus, gives a generation excess of 6.2 kW, provoking a rapid voltage rise in the dc bus at the time that the dc load is disconnected (t_1) . When the dc voltage reach the maximum value (620 V), the chopper connects the resistor to burn the required power to drop the voltage below the maximum. At the same time the battery power reference begins to change in order to work in charging mode and absorb the extra power. The peak power absorbed by the VLR is 3 kW, once the battery begins to absorb power and the VLR is disconnected. Before reaching t_2 and the steady state is nearly reached. The PV module is injected 6.4 kW the ac load is absorbing 3.2 kW and the battery is charging at a 3.2 kW rate. The dc voltage is being reduced at nearly 600 V. Analysing the ac part between t_1 and t_2 , no change is observed since the main converter power reference is not changed and the ac voltage remains at is rated value.

At $t_2 = 0.7 \ s$ the ac voltage suffers a drop of 5 V. Intermediately, the main converter begins to inject reactive power trying to compensate this voltage drop. At the dc part, no important changes are observed. The amplitude of currents injected in the system by the main converter increase as it can be observed in Fig. 6(e). Due to the droop configuration, a change of 5 V in the voltage will produce a variation of 12 kVA. At steady state, the main converter would inject 12 kVA and the ac load would absorb 3.2 kVA, so 8.8 kVA would be injected to the main grid.

At $t_3 = 0.8$ the second ac load is connected when the steady state has not been reached yet. Both ac loads will absorb 4.7 kW and 4.7 kVAr. At the first instants part of the active power is absorbed from the grid because the rate of variation of the power reference at the main converter is limited to guaranty the voltage stability at the dc bus. In the dc bus, the PV module is generating 6.2 kW and the battery rate of charge is reduced to 1.5 kW to inject the rest of the power (4.7 kW) to the ac part. Regarding the reactive power, the main converter injects 12 kVA and the load absorbs 4.7 kVA, so the extra reactive power 6.3 kVA, is injected into the network.

At $t_4 = 1.1$, the dc load is connected again, now the power balance is the next; the PV panel is generating 6.2 kW, the ac load absorbs 4.7 kW and the dc load would absorb 5.9 kW. Actually the dc load absorb a lower amount of power during the first instants derived from the voltage drop caused by power unbalance at the time of the dc load connection. The battery will change its working mode, and will start working in discharging mode with a rate of discharge of 4.5 kW the extra power injected at the dc bus is used to increase the dc bus voltage.

At $t_5 = 1.3 s$, the ac voltage is increased in 5 V. At this voltage, the ac load will consume 5 kW that will be provided by the main converter since the P_{ref}^A is still zero. Due to the droop control, the main converter will try to reduce the grid voltage absorbing and given amount of reactive power determined by the value of the droop (in this case 12 kVA). The grid will provide the reactive power (5 kVA consumed by the load at this voltage level) plus the 12 kVA consumed by the main converter. The total amount of reactive power imported from the grid is about 17 kVA. There are no significant changes in the dc bus (at t_6 the voltage is nearly in its rated value 600 V).

At $t_6 = 1.5 s$ the active power reference at the point labeled as "A" is set to $P_{ref}^A = 2$ kW. This means that the building must import 2 kW from the network. The load absorbs 5 kW, 3 kW from the main converter and 2 kW from the grid. The dc bus voltage is near the rated value so the dc load is absorbing around 6 kW. The PV is injecting 6.4 kW and the main converter is transferring 3 kW to the ac part. In this case the battery must provide most of the power transferred from the dc subsystem to the ac one.

At $t_7 = 1.8 \ s$, the active power reference at A is set to $P_{\text{ref}}^A = 6 \ \text{kW}$. In this case, the building is absorbing 6 kW from the main grid, but the load is only consuming 5 kW, so the main converter must transfer 1 kW from the ac part to the

dc part. Since the PV generation and the dc load are nearly balanced, the extra power transferred from the ac part is used to charge the battery.

At $t_8 = 2.1 \ s$, the active power reference at A is set to $P_{\text{ref}}^A = -3 \ \text{kW}$, and the whole building will act as a generator. The main converter must supply 5 kW demanded by the load plus 3 kW that must be injected into the network being the total amount of active power 8 kW. Most of this power must be supplied by the battery, that is why at the first instants, there is an important voltage drop at the dc bus due to the limitations of the battery references rate of change.

At $t_9 = 2.4 \ s$, the active power reference at A is set to $P_{\text{ref}}^A = -1 \ \text{kW}$, and the dc voltage is again near the rated value. At the same time the ac voltage suffers a drop of 12 V (from 405 to 393 V) so the main converter will become again a reactive power generator, supplying the load requirements plus a grid injection of 10 kVA. Reagarding the active power, the main converter will inject 5.5 kW to the ac part. 1 kW is injected into the grid and 4.5 kW are consumed by the load.

At $t_{10} = 2.7 \ s$, the active power reference at *A* is set to $P_{\text{ref}}^A = 0$ again, so the building will be invisible for the grid in terms of active power consumption. The grid voltage is set to 400 V, so no reactive power injection will be required from the main converter and the dc load will be switched off. The PV generation will be 6.4 kW and the ac demand of 4.7 kW so the extra power will be used to charge the battery. At the first instants after the dc load disconnection, the dc voltage will rise again due to the battery references limitations and the VLR will be activated to limit the voltage rise to its maximum preset value of 620 V.

V. TESTS WITH THE REAL PROTOTYPE

As an example, the authors provide in this section some tests developed with the real prototype. In Fig. 7, the obtained data during the tests are depicted. The data correspond to a test carried out for 20 min. The building ac load varied in a range from 101 to 120 kW. The P_{ref}^A was set to 105 kW. During the whole test the voltage at the PC was equal to its rated value so there was not reactive power injection. The main converter injected the difference between the power demanded by the load and P_{ref}^A . Most of the time, this difference was positive so the main converter transferred power from the dc side to the ac side, but at $t \simeq 360$ s. the ac power demand drooped below P_{ref}^A (near 100 kW), so the main converter had to absorb power injecting it into the dc bus. The dc load is $\simeq 4.8$ kW, most of this load is used for the ventilation system. All the power into the dc bus through the main converter was used to supply the dc load, during this case study the battery did not work in charging mode. At $t \simeq 630 \ s$ the building power demand raised again over P_{ref}^A and the main converter began to transfer again active power from the dc part to the ac part of the system. In Fig. 7(c), the voltage at the dc bus is depicted. It can be observed that when the ac load is reduced the voltage is increased at the dc bus and vice versa. In this case there was an error of 2 V with respect to the reference in the steady state dc bus voltage and the maximum voltage variation during the test was ± 5 V. The sample frequency was 1 Hz.





Fig. 7. Case study. (a) Active power at the ac part of the system (kW). (b) Active power at the dc part of the system (kW) and active power provided by the main converter. (c) DC bus voltage (V).

VI. CONCLUSION

In this paper, a CPD and its operation in a zero grid impact building was presented. This kind of configuration allows the building to control the amount of active and reactive power can be imported or exported from the grid, making the building acting as a dispatchable load or generator. This could be very helpful to achieve large penetration levels of DG in the LV grid. Moreover, the device is also capable of providing ancillary services as voltage support by increasing the reactive power injection when the grid voltage is below its rated value. As it was stated, the proposed device has two different subsystems. The ac subsystem consists on the building ac loads and the dc system can include different kind of devices. The use of this innovative configuration combining ac/dc distribution inside the building has been tested. In this case, the real prototype has a energy storage system based in Li-Po batteries, a VLR and different dc loads, most of them for ventilation and heating purposes. The ac part and the dc part are connected through an ac/dc converter. It has been also studied in the simulations the possibility of inserting a PV generator in the dc system. The proposed controls for each element of the system have been tested and the simulations have demonstrated that the system is stable under all possible scenarios. Finally, the real tests showed how the system makes the whole building a dispatchable load or generator. In this case it is not possible to achieve a situation where no power is imported from the grid because the prototype is connected to a building with a rated power much higher than the storage system power. Further works should include studies of load profiles and capacities of different storage and generation devices in order to develop a proper sizing procedure to achieve the zero grid impact.

IEEE TRANSACTIONS ON SMART GRID

REFERENCES

- J. H. Yoon, R. Baldick, and A. Novoselac, "Dynamic demand response controller based on real-time retail price for residential buildings," *IEEE Trans. Smart Grid*, vol. 5, no. 1, pp. 121–129, Jan. 2014.
- [2] C. Vivekananthan, Y. Mishra, G. Ledwich, and F. Li, "Demand response for residential appliances via customer reward scheme," *IEEE Trans. Smart Grid*, vol. 5, no. 2, pp. 809–820, Mar. 2014.
- [3] B. Moradzadeh and K. Tomsovic, "Two-stage residential energy management considering network operational constraints," *IEEE Trans. Smart Grid*, vol. 4, no. 4, pp. 2339–2346, Dec. 2013.
- [4] M. Sullivan, J. Bode, B. Kellow, S. Woehleke, and J. Eto, "Using residential AC load control in grid operations: PG&E's ancillary service pilot," *IEEE Trans. Smart Grid*, vol. 4, no. 2, pp. 1162–1170, Jun. 2013.
- [5] C. Murillo-Sanchez, R. Zimmerman, C. L. Anderson, and R. Thomas, "Secure planning and operations of systems with stochastic sources, energy storage, and active demand," *IEEE Trans. Smart Grid*, vol. 4, no. 4, pp. 2220–2229, Dec. 2013.
- [6] M. C. Falvo, "Generation and transmission planning and electricity market: The role of TSO," in *Proc. 7th Int. Conf. Eur. Energy Market (EEM)*, Madrid, Spain, 2010, pp. 1–6.
- [7] R. Argiento, R. Faranda, A. Pievatolo, and E. Tironi, "Distributed interruptible load shedding and micro-generator dispatching to benefit system operations," *IEEE Trans. Power Syst.*, vol. 27, no. 2, pp. 840–848, May 2012.
- [8] G. Parise, L. Martirano, and L. Parise, "Ecodesign of ever net-load microgrids," *IEEE Trans. Ind. Appl.*, vol. 50, no. 1, pp. 10–16, Jan. 2014.
- [9] A. Ipakchi and F. Albuyeh, "Grid of the future," *IEEE Power Energy Mag.*, vol. 7, no. 2, pp. 52–62, Mar. 2009.
- [10] P. Kadurek, J. Cobben, W. Kling, and P. Ribeiro, "Aiding power system support by means of voltage control with intelligent distribution substation," *IEEE Trans. Smart Grid*, vol. 5, no. 1, pp. 84–91, Jan. 2014.
- [11] C. Gonzalez-Moran, P. Arboleya, D. Reigosa, G. Diaz, and J. Gomez-Aleixandre, "Improved model of photovoltaic sources considering ambient temperature and solar irradiation," in *Proc. IEEE PES/IAS Conf. Sustain. Altern. Energy (SAE)*, Valencia, Spain, 2009, pp. 1–6.



Pablo Arboleya (SM'13) received the M.Sc. and Ph.D. (with distinction) degrees from the University of Oviedo, Gijon, Spain, in 2001 and 2005, respectively, both in electrical engineering.

He is currently an Associate Professor with the Department of Electrical Engineering, University of Oviedo. His current research interests include micro-grid and smartgrid modeling and operation techniques, railway traction networks simulation, and combined ac/dc power flow algorithms.



Cristina Gonzalez-Moran (M'12) received the M.Sc. and Ph.D. degrees from the University of Oviedo, Gijon, Spain, in 2003 and 2010, respectively, both in electrical engineering.

She is currently an Associate Professor with the Department of Electrical Engineering, University of Oviedo. Her current research interests include renewable energies, distributed generation and microgrids modeling, simulation, design, and optimization.



Manuel Coto (M'11) received the M.Sc. and Ph.D. degrees from the University of Oviedo, Gijon, Spain, in 2007 and 2012, respectively.

He is currently with the Department of Electrical Engineering, University of Oviedo. His current research interests include the area of power-flow and ac/dc power systems modeling and simulation. ARBOLEYA et al.: EFFICIENT ENERGY MANAGEMENT IN SMART MGs: ZERO GRID IMPACT BUILDINGS



Maria Carmen Falvo (SM'13) received the M.Sc. and Ph.D. degrees in electrical engineering, both from the University of Rome "Sapienza," Rome, Italy, in 2002 and 2007, respectively.

She has been with the Department of Electrical Engineering, the University of Rome "Sapienza," as an Assistant Professor since 2008. Her current research interests include power systems simulation, smartgrids, and power systems for electrical mobility.

Ms. Falvo is a member of Italian Electric Association from 2001 and the IEEE-PES from 2004.



Ilaria Bertini received the M.Sc. degree in electrical engineering.

She is currently a Deputy Director of the Technical Unit Energy Efficiency, Italian National Agency for New Technologies, Energy and Sustainable Economic Development. Her current research interests include diagnostics, monitoring, and control systems for power generation, the application and dissemination of emerging efficient technologies and design of prototypical interventions aimed at the efficient retrofit of buildings

and at the optimization of energy resources locally produced in the energy districts (heating-cooling districts).



Luigi Martirano (SM'12) received the M.Sc. and Ph.D. degrees in electrical engineering from the University of Rome, Rome, Italy, in 1998 and 2002, respectively.

In 2000, he joined the Department of Electrical Engineering of the University of Rome "La Sapienza," Rome. He is currently an Assistant Professor of Building Automation and Energy Management at the Engineering Faculty. His current research interests include cover power systems design, planning, safety, lightings, home and build-

ing automation, and energy management.



Danilo Sbordone received the B.Sc. and M.Sc. degrees in telecommunication engineering from the University of Rome "Sapienza," Rome, Italy, in 2006, where he is currently pursuing the Ph.D. degree.

He is currently with the Italian National Agency for New Technologies Energy and Sustainable Economic Development and FREEDM Center, North Carolina State University, Raleigh, NC, USA. His current research interests include monitoring and control energy systems and in the optimization of

efficiency in smart grids.



Biagio Di Pietra received the M.Sc. degree in electrical engineering and the Ph.D. degree in technical physics.

He has been a Researcher with a permanent contract at Italian National Agency for New Technologies, Energy and Sustainable Economic Development since 2004. His current research interests include building model, electric grid, and district heating energy efficiency, solar thermal plants, and electric storage energy efficiency.