# Cost-Based Droop Schemes for Economic Dispatch in Islanded Microgrids

Feixiong Chen, Minyou Chen, Senior Member, IEEE, Qiang Li, Kaikai Meng, Yongwei Zheng, Josep M. Guerrero, Fellow, IEEE, and Derek Abbott, Fellow, IEEE

*Abstract*—In this paper, cost-based droop schemes are proposed, to minimize the total active power generation cost in an islanded microgrid (MG), while the simplicity and decentralized nature of the droop control are retained. In cost-based droop schemes, the incremental costs of distributed generators (DGs) are embedded into the droop schemes, where the incremental cost is a derivative of the DG cost function with respect to output power. In the steady state, DGs share a single common frequency, and cost-based droop schemes equate incremental costs of DGs, thus minimizing the total active power generation cost, in terms of the equal incremental cost principle. Finally, simulation results in an islanded MG with high a penetration of intermittent renewable energy sources are presented, to demonstrate the effectiveness, as well as plug and play capability of the cost-based droop schemes.

*Index Terms*—Microgrid (MG), incremental cost, generation cost, cost based droop schemes, decentralized control.

## I. INTRODUCTION

**F** ACING the challenges arising from fossil fuel exploitation and associated pollution, people now turn their attention to the renewable energy resources [1]. Note that the microgrid (MG) is considered as a solution for flexible and reliable integration of renewable energy resources into the main grid. An MG is a cluster of distributed generators (DGs), storage systems, and loads, which is connected to the main grid at the point of common coupling, and it operates in either

Manuscript received January 7, 2016; revised March 24, 2016 and May 9, 2016; accepted June 12, 2016. Date of publication June 15, 2016; date of current version December 21, 2016. This work was supported in part by the National Natural Science Foundation of China under Grant 51177177 and Grant 61105125, and in part by the National "111" Project under Grant B08036. Paper no. TSG-00027-2016.

F. Chen, M. Chen, and Q. Li are with the State Key Laboratory of Power Transmission Equipment & System Security and New Technology, School of Electrical Engineering, Chongqing University, Chongqing 400044, China (e-mail: chenfeixiong87@sina.com; mchencqu@126.com; qiangli.ac@gmail.com).

K. Meng is with the Fuzhou Power Supply Company of State Grid Fujian Electric Power Company, Fujian 350000, China (e-mail: mkk20121102067@163.com).

Y. Zheng is with the Neijiang Electric Power Supply Company of State Grid Sichuan Electric Power Company, Sichuang 641000, China (e-mail: aoyun200888pm8@126.com).

J. M. Guerrero is with the Department of Energy Technology, Aalborg University, Aalborg East 9220, Denmark (e-mail: joz@et.aau.dk).

D. Abbott is with the School of Electrical and Electronic Engineering, University of Adelaide, Adelaide, SA 5005, Australia (e-mail: derek.abbott@adelaide.edu.au).

Color versions of one or more of the figures in this paper are available online at http://ieeexplore.ieee.org.

Digital Object Identifier 10.1109/TSG.2016.2581488

islanded mode or grid-connected mode, and it is able to perform seamless transitions between these two modes. In the grid-connected mode, the power shortfall can be compensated by the main grid, and the excess power in the MG can be absorbed by the main grid. When islanded, the power generation of DGs ought to be in balance with the total load demand in the MG [2].

Conventionally, the centralized control is implemented for islanded MGs, where the control decisions are performed based on global information, requiring an extensive communication network between the MG central controller (MGCC) and DGs. On the contrary, in distributed control, the decision making is performed based on local information, and it requires no MGCC and extensive communication network. Moreover, it assumes that the interactions among DGs are negligible in decentralized control, and the requirement for communication network is obviated. Therefore, the distributed and decentralized control methods are more practical for a large sized MG than centralized control, due to their flexibilities in plug and play, as well as sparse communication channels, etc [3]–[5].

Note that the distributed techniques for the secondary control [6]–[11] and proportional power sharing [12]–[17] have been extensively studied. However, the stability of voltage and frequency, as well as proportional power sharing might not be comprehensive enough for the MG, where both the generation costs and emission penalties are different for different types of DGs. Therefore, the economic dispatch is desired, which aims at distributing generation responsibility among DGs in an economical manner, while satisfying both equality and inequality constraints in the MG [18]. In the last few years, the efforts toward the distributed economic dispatch have been performed. Based on JADE platform and multiagent system (MAS), Zhang et al. [19] proposed a distributed gradient based algorithm, to minimize the total active power generation cost online. Later, further work was carried out to integrate the economic dispatch and demand response management together [20]. Additionally, considering the generation and ramping rate limits of DGs, an MAS based dynamic programming algorithm was developed, to minimize the total power generation cost [21].

On the other hand, the consensus algorithms have found their applications in economic dispatch. First, it is worth noting that the total generation cost of the MG is minimized so long as the incremental costs of DGs are equal, i.e., *the equal incremental cost principle*, where the incremental cost

1949-3053 © 2016 IEEE. Personal use is permitted, but republication/redistribution requires IEEE permission. See http://www.ieee.org/publications\_standards/publications/rights/index.html for more information.

is a derivative of the DG cost function with respect to output power [22], [23]. Therefore, the incremental cost was chosen as the consensus variable, and a consensus algorithm was developed to drive incremental costs of DGs to a common value [24]. In [25], a consensus algorithm for equal incremental costs was formulated, which required a strongly connected communication for information exchanges. Additionally, the incremental welfare consensus algorithm with the consideration of responsive loads was proposed [26]. Further, a network consisting of cooperative dynamic agents was formulated to solve the cost minimization problem in a distributed manner [27]. Considering the power losses and generation limits, a distributed solution for the cost minimization problem was provided in [23]. Moreover, the consensus algorithm with exponential convergence rate was explored in [28]. And Binetti et al. [29] focused on an economic dispatch model incorporating the transmission losses, power generation constraints and prohibited operating zones. Considering the impacts of intermittent DGs, a fully distributed consensus algorithm was proposed for social welfare maximization of both the users and energy providers [30]. Similar work was carried out in [31], where both the conventional thermal DGs and wind turbines were taken into consideration. Moreover, a fully distributed strategy integrating the frequency recovery and economic dispatch in one process was developed in [32].

As discussed above, the economic dispatch problem was effectively solved by consensus algorithms in distributed manners, and the consensus algorithms precluded the need for a centralized coordinator so that they were fully distributed. On the other hand, the consensus algorithms were implemented with asynchronous or synchronous communications. In other words, the units in the communication network updated and exchanged information with other units synchronously or asynchronously, which may degrade the convergence speed [21]. Moreover, the consensus algorithms were highly dependent on the communication network for information exchange, and the malfunction of communication links may possibly result in the invalid algorithms.

Therefore, the vulnerabilities of the consensus algorithms prompted the interest in cost based droop schemes, which required neither communication network nor interactions among DGs. Note that Xin et al. [33], [34] proposed a fully distributed control strategy for frequency-power and powerfrequency droop type DGs, respectively, which allowed all DGs share loads according to their generation costs, however, the capability of plug and play was not demonstrated. With the consideration of generation costs, efficiencies, and emission penalties of DGs, Nutkani et al. [18], [35], [36] formulated nonlinear droop schemes to allow the least costly DG produce more power. Further work was carried out in [37], where the costlier DGs were turned OFF when the load was light, to achieve a reduction in no-load cost. Considering the lower accuracy and increased complexity of the nonlinear droop control, a linear droop scheme was proposed to achieve a reduction in generation cost [38]. Later, the constraints such as online power reserve, frequency, voltage, and power limits were taken into consideration [39].

By embedding the generation costs into the droop control, the cost based droop schemes discussed in [18] and [35]–[39] allowed autonomous identification of the appropriate DGs for generation, in terms of the generation cost. Therefore, compared to traditional droop control, the cost based droop schemes demonstrated significant effectiveness in the reduction of the total generation cost of the MG. On the other hand, the cost based droop control schemes were incapable of keeping the total generation cost to a minimum, because the power outputs of the DGs were tuned according to their respective generation costs rather than the total generation cost of the MG.

To address these concerns, the alternative cost based droop schemes are developed in this paper, which are implemented by embedding the incremental costs into the droop control. The cost based droop schemes have the functionality for driving the incremental costs of DGs to a consensus value, therefore, the total active power generation cost of the MG is minimized, in terms of the equal incremental cost principle. Furthermore, the simplicity, the capability of plug and play, as well as the decentralized nature of the droop control are preserved. In practical applications, the plug and play capability allows the plug out operation of the faulted DG, while maintaining the optimal operation states of remaining DGs. Moreover, when the DG is plugged back to the MG after the repair and maintenance, the control schemes with plug and play capability are able quickly to drive the incremental costs of DGs to a consensus value, to minimize the total active power generation cost of the MG.

Compared to the existing methods, the salient features of the proposed cost based droop schemes are (i) they require no complicated mathematical modeling, and they are simple enough to be implemented, therefore making them more suitable for practical applications; (ii) they are fully decentralized and require no communication network among DGs, therefore, they offer increased reliability; (iii) they have the capability of plug and play, therefore, the plug out and plug in behaviors of DGs do not affect the performance of the control schemes. Finally, five cases are performed, and simulation results show that the total active power generation cost of the MG is minimized, while satisfying given constraints, in the presence of intermittent DGs and highly variable load demands.

The rest of the paper is organized as follows. The economic dispatch problem and the equal incremental cost principle are introduced in Section II. And in Section III, the structure and parameters of the islanded MG under study are introduced and listed, further, the cost based droop schemes are developed. Later, in Section IV, five cases are carried out to evaluate the performance of the cost based droop schemes, and then the simulation results are analyzed and discussed. Finally, Section V concludes the paper.

## **II. PROBLEM FORMULATION**

This section introduces the economic dispatch problem for islanded MGs, which aims at minimizing the total active power generation cost. Further, the economic dispatch problem is solved by the Lagrangian method, and then the equal incremental cost principle is presented.

## A. Economic Dispatch Problem

For the case that there are a total of *n* DGs in an islanded MG, the *i*th DG has a cost function  $C_i(P_i)$ . And it is assumed that the photovoltaic (PV) and wind generation, as well as reactive power generation are free. Note that the transmission loss is small in the MG, which is about 3–5% of the total load, therefore, the transmission loss  $P_{\text{loss}}$  can be approximately represented by multiplying the total load demand  $P_D$  by 5% [20], [30], [40].

Thereafter, with the aim of minimizing the total active power generation cost, while satisfying power balance and power generation constraints, the economic dispatch problem being considered in this paper can be expressed as

$$\min \sum_{i=1}^{n} C_i(P_i), \tag{1}$$

$$\sum_{i=1}^{n} P_i = P_D + P_{\text{loss}} = (1+5\%) \cdot P_D, \qquad (2)$$

$$P_i^{\min} \le P_i \le P_i^{\max},\tag{3}$$

where  $P_i$  is the active power output of  $DG_i$ ,  $C_i(P_i)$  is the cost function of  $DG_i$ ,  $P_D$  is the total active load demand in the MG,  $P_{loss}$  is the transmission loss, and  $P_i^{\min}$ ,  $P_i^{\max}$  are lower and upper limits of active power generation of  $DG_i$ , respectively.

#### B. The Equal Incremental Cost Principle

The economic dispatch problem formulated in (1) can be solved by the Lagrangian method, and the corresponding Lagrangian function takes the following forms [22], [23],

$$L(P_1, P_2 \cdots, P_n) = \sum_{i=1}^{n} C_i(P_i) + \lambda \cdot \left(P_D + P_{\text{loss}} - \sum_{i=1}^{n} P_i\right) + u_1 \cdot \left(P_i - P_i^{\max}\right) + u_2 \cdot \left(P_i^{\min} - P_i\right),$$
(4)

where  $\lambda$ ,  $u_1$ , and  $u_2$  are Lagrange multipliers.

U

In terms of first order optimality conditions, we have

$$\frac{\partial L}{\partial P_i} = \frac{\partial C_i(P_i)}{\partial P_i} - \lambda + u_1 - u_2 = 0, \quad (5)$$

$$\frac{\partial L}{\partial \lambda} = P_D + P_{\text{loss}} - \sum_{i=1}^n P_i = 0, \tag{6}$$

$$\frac{\partial L}{\partial u_1} = P_i - P_i^{\max} \le 0,\tag{7}$$

$$\frac{\partial L}{\partial u_2} = P_i^{\min} - P_i \le 0, \tag{8}$$

$$u_1 \cdot \left( P_i - P_i^{\max} \right) = 0, \tag{9}$$

$$u_2 \cdot \left( P_i^{\min} - P_i \right) = 0, \tag{10}$$

$$u_1, u_2 \ge 0.$$
 (11)

If  $P_i^{\min} < P_i < P_i^{\max}$ , according to (9), (10) and (11), it yields

$$u_1 = u_2 = 0. (12)$$

Applying conditions (12) to (5), we have

$$\lambda^* = \frac{\partial C_i(P_i)}{\partial P_i} = \lambda_i, \tag{13}$$

where  $\frac{\partial C_i(P_i)}{\partial P_i} = \lambda_i$  is the incremental cost of DG<sub>i</sub>, and  $\lambda^*$  is the optimal incremental cost of DG<sub>i</sub>.

Similarly, if  $P_i = P_i^{\text{max}}$ , according to (5), (9), (10) and (11), it yields

$$\begin{cases} u_1 \ge 0, \\ u_2 = 0, \\ \lambda^* = \frac{\partial C_i(P_i)}{\partial P_i} \Big|_{P_i = P_i^{\max}} + u_1 \ge \frac{\partial C_i(P_i)}{\partial P_i} \Big|_{P_i = P_i^{\max}} = \lambda_i. \end{cases}$$
(14)

And if  $P_i = P_i^{\min}$ , similar relationship between  $\lambda^*$  and  $P_i$  can be obtained as follows,

$$\begin{cases} u_1 = 0, \\ u_2 \ge 0, \\ \lambda^* = \frac{\partial C_i(P_i)}{\partial P_i} \Big|_{P_i = P_i^{\min}} - u_2 \le \frac{\partial C_i(P_i)}{\partial P_i} \Big|_{P_i = P_i^{\min}} = \lambda_i. \end{cases}$$
(15)

Finally, the solution to (1) can be obtained, which is the *equal incremental cost principle*, and it takes the following forms,

$$\begin{cases} \lambda_{i} = \frac{\partial C_{i}(P_{i})}{\partial P_{i}} = \lambda^{*} \quad P_{i}^{\min} < P_{i} < P_{i}^{\max}, \\ \lambda_{i} = \frac{\partial C_{i}(P_{i})}{\partial P_{i}} \leq \lambda^{*} \quad P_{i} = P_{i}^{\max}, \\ \lambda_{i} = \frac{\partial C_{i}(P_{i})}{\partial P_{i}} \geq \lambda^{*} \quad P_{i} = P_{i}^{\min}. \end{cases}$$
(16)

The equal incremental cost principle in (16) denotes that the total active power generation cost of the MG is minimized, if only the equal incremental cost principle is satisfied. Moreover, in this case, the DGs that operate within power generation limits have the equal incremental cost of  $\frac{\partial C_i(P_i)}{\partial P_i}$ , and DGs have the incremental costs of  $\frac{\partial C_i(P_i)}{\partial P_i}|_{P_i=P_i^{\text{max}}}$ or  $\frac{\partial C_i(P_i)}{\partial P_i}|_{P_i=P_i^{\text{min}}}$ , when operating on their upper or lower generation limits, respectively.

## III. INCREMENTAL COST BASED DROOP SCHEMES

In this section, the structure and parameters of the islanded MG for test is introduced first. Next, how the nonlinear and linear cost based droop schemes are derived from the exponential and quadratic cost functions is investigated, respectively.

#### A. The Structure and Parameters of the Islanded MG

In this paper, an islanded MG shown in Fig. 1 is considered, which is established in MATLAB/Simulink. The specifications of loads and power ratings of intermittent DGs are listed in Fig. 1. Here, DG<sub>1</sub> and DG<sub>3</sub> are PVs, while DG<sub>6</sub>, DG<sub>8</sub> and DG<sub>9</sub> are permanent magnet synchronous generator (PMSG) based wind turbines, all of which operate in maximum power point tracking (MPPT) control mode. Additionally, dc-links of controllable DGs, DG<sub>2</sub>, DG<sub>4</sub>, DG<sub>5</sub>, DG<sub>7</sub> and DG<sub>10</sub> are modeled as constant dc voltage sources  $V_{dc}$ , and we assume that the voltage variations of dc-links are well regulated. And controllable DGs operate in terms of the cost based droop schemes. Moreover, the line impedance of low-voltage transmission lines in the MG is set at  $0.642 + j0.083 \Omega/km$ .



Fig. 1. Schematic diagram of an islanded MG with radial structure.

## B. Traditional Linear Droop Scheme

In an islanded droop-controlled MG, the active power output of a DG is controlled by adjusting frequency of the voltage reference [41]. Further, the  $P-\omega$  droop control is implemented as follows,

$$f_i = f^{\max} - \frac{f^{\max} - f^{\min}}{P_i^{\max}} \cdot P_i, \qquad (17)$$

where  $f_i$  is the frequency of DG<sub>i</sub>, and  $f^{\text{max}} = 51$  Hz,  $f^{\text{min}} = 49$  Hz, which are maximum and minimum frequencies allowed by the MG, respectively [42].

Furthermore, the traditional droop curves are plotted in Fig. 2, where droop curves are overlapped. And it is found in Fig. 2 that equations  $P_2(p.u.) = P_4(p.u.) = P_5(p.u.) = P_7(p.u.) = P_{10}(p.u.)$  are always satisfied, because DGs share a single common frequency in the steady state. In other words, active power outputs of DGs are always proportional to their respective power ratings. On the other hand, both the generation costs and emission penalties are different for different types of DGs. Therefore, the total active power generation cost of the MG is not minimized, when the traditional linear droop scheme is implemented.

### C. Nonlinear Cost Based Droop Scheme

In order to minimize the total active power generation cost, the *nonlinear cost based droop scheme* is developed in this subsection. First, it is assumed that the *i*th DG has an



Fig. 2. Traditional linear droop scheme.

 TABLE I

 Cost Coefficients of Exponential Cost Functions

DG	а	b	С	d	$P^{\min}$	$P^{\max}$
DG <sub>2</sub>	0.50552	0.08290	3.33	-0.02094	0	45 kW
$DG_4$	0.65912	0.06259	2.857	0.10762	0	30 kW
$DG_5$	0.47936	0.04552	2.857	0.07827	0	40 kW
DG <sub>7</sub>	0.35952	0.03414	2.857	0.05870	0	45 kW
$DG_{10}$	0.26964	0.02561	2.857	0.04430	0	20 kW



Fig. 3. Incremental cost curves with exponential cost functions.

exponential cost function  $C_i(P_i)$  including the maintenance cost, fuel cost, emission penalty and no-load cost, which takes the following forms [18], [34],

$$C_i(P_i) = \alpha_i \cdot P_i^2 + \beta_i \cdot \exp(\gamma_i \cdot P_i) + \delta_i \cdot P_i + \epsilon_i, \quad (18)$$

where  $\alpha_i$ ,  $\beta_i$ ,  $\gamma_i$ ,  $\delta_i$ ,  $\epsilon_i$  are cost coefficients.

Therefore, for *i*th DG, the incremental cost can be obtained

$$\lambda_{i} = \frac{\partial C_{i}(P_{i})}{\partial P_{i}} = 2\alpha_{i} \cdot P_{i} + \beta_{i} \cdot \gamma_{i} \cdot \exp(\gamma_{i} \cdot P_{i}) + \delta_{i}$$
$$= a_{i} \cdot P_{i} + b_{i} \cdot \exp(c_{i} \cdot P_{i}) + d_{i}, \qquad (19)$$

where  $2\alpha_i = a_i$ ,  $\beta_i \cdot \gamma_i = b_i$ ,  $\gamma_i = c_i$  and  $\delta_i = d_i$ .

Furthermore, the cost coefficients and power generation limits of controllable DGs are summarized in Table I [18], [34], and the incremental cost curves are plotted in Fig. 3 correspondingly. Note that the equal incremental cost principle



(a) Nonlinear cost based droop scheme without the parameter k.



(b) Nonlinear cost based droop scheme with the parameter k.

Fig. 4. Nonlinear cost based droop scheme.

discussed in Section II is equivalent to draw horizontal lines in Fig. 3. Therefore, different levels of active power outputs (p.u.) can be read from their respective points, and it clearly denotes that the load demands are not proportionally shared among controllable DGs, and DG<sub>10</sub> always has the highest level of output power, when DGs operate at the equal incremental cost. Moreover, it can be found in Fig. 3 that the incremental costs of DG<sub>2</sub>, DG<sub>4</sub>, DG<sub>5</sub>, DG<sub>7</sub>, DG<sub>10</sub> remain constant at 2.8, 1.85, 1.35, 1, 0.76, when power outputs reach their respective upper limits, respectively.

In order to minimize the total active power generation cost, we have developed the nonlinear cost based droop scheme. First, the traditional droop expression in (17) has to be modified to (20), where the incremental cost is introduced into (17) and the corresponding cost based droop curves are plotted in Fig. 4(a),

$$f_i = f^{\max} - \left(f^{\max} - f^{\min}\right) \cdot \frac{\partial C_i(P_i)}{\partial P_i}.$$
 (20)

In this paper, the no-load and full-load frequencies are set at 51 Hz and 49 Hz, respectively, to limit the frequency of the MG within the allowable range. However, the introduction of the incremental costs into the droop schemes results in the frequency violation, as shown in Fig. 4(a), where it can

 TABLE II

 Cost Coefficients of Quadratic Cost Functions

DG	d	е	$P^{\min}$	$P^{\max}$
DG <sub>2</sub>	0.094	1.22	0	45 kW
$DG_4$	0.078	3.41	0	30 kW
$DG_5$	0.105	2.53	0	40 kW
$DG_7$	0.082	4.02	0	45 kW
DG10	0.074	3.17	0	20 kW

be observed that the frequency is lower than the minimum frequency permitted by the MG, when  $DG_2$ ,  $DG_4$ , and  $DG_5$  operate at their respective upper limits.

On the other hand, it is desired that the frequency is regulated within the permissible range, to ensure the stability of the MG, which can be achieved by tuning the gradients of droop curves. Following this idea, a parameter k is added to the droop equation in (20) to arrive at the proposed cost based droop scheme in (21)

$$\begin{cases} f_i = f^{\max} - \left( f^{\max} - f^{\min} \right) \cdot k \cdot \frac{\partial C_i(P_i)}{\partial P_i}, \\ \min(f_2, f_4, f_5, f_7, f_{10}) > f^{\min} = 49, \\ \max(f_2, f_4, f_5, f_7, f_{10}) < f^{\max} = 51. \end{cases}$$
(21)

In terms of (21), a number of solutions for k can be obtained, and k is taken as 0.357 in this paper. Note that the parameter k is properly chosen before the implementation of the cost based droop scheme, while requiring no communication network for information exchanges among DGs, when the system is running.

Finally, in terms of (21), the cost based droop curves are plotted in Fig. 4(b), where the droop curves are nonlinear, and the frequency of the MG stays within the allowable range. Moreover, in the steady state, DGs share a single common frequency, according to (21), we have

$$\frac{\partial C_2(P_2)}{\partial P_2} = \frac{\partial C_4(P_4)}{\partial P_4} = \frac{\partial C_5(P_5)}{\partial P_5} = \frac{\partial C_7(P_7)}{\partial P_7}$$
$$= \frac{\partial C_{10}(P_{10})}{\partial P_{10}},$$
(22)

which denote that the nonlinear cost based droop scheme equates the incremental costs of controllable DGs. Therefore, in terms of the equal incremental cost principle, the total active power generation cost is minimized.

## D. Linear Cost Based Droop Scheme

On the other hand, considering the fuel cost, the generation cost of *i*th DG can also be approximated with a quadratic cost function, which takes the following forms [19], [23],

$$C_i(P_i) = d_i \cdot P_i^2 + e_i \cdot P_i + f_i, \qquad (23)$$

where  $d_i$ ,  $e_i$ ,  $f_i$  are cost coefficients.

Moreover, the cost coefficients are listed in Table II [28], and for *i*th DG, the incremental cost can be derived,

$$\lambda_i = \frac{\partial C_i(P_i)}{\partial P_i} = 2d_i \cdot P_i + e_i.$$
(24)

Furthermore, similar to the derivation process of the nonlinear cost based droop scheme, the cost based droop



Fig. 5. Incremental cost curves with quadratic cost functions.



Fig. 6. Linear cost based droop scheme.

scheme derived from the quadratic cost function takes the following forms,

$$f_i = f^{\max} - \left( f^{\max} - f^{\min} \right) \cdot h \cdot \frac{\partial C_i(P_i)}{\partial P_i}, \qquad (25)$$

where h = 0.1.

Thereafter, the incremental cost curves and droop curves are plotted in Fig. 5 and Fig. 6, respectively. It can be seen in Fig. 5 and Fig. 6 that both of the incremental cost curves and droop curves are linear, termed here the linear cost based droop scheme. Similarly, in the steady state, DGs share a single common frequency, therefore, the equations in (22) are fulfilled, and the minimum generation cost is achieved, in terms of the equal incremental cost principle.

## **IV. RESULTS**

In this section, the performance of the cost based droop schemes are tested on the islanded MG shown in Fig. 1, and five simulation cases are presented and discussed in detail. In case 1, the nonlinear cost based droop scheme derived from the exponential cost function is utilized, and case 1 focuses on responses of the nonlinear cost based droop scheme to the fluctuation of intermittent DGs. For case 2, the large changes in load demands are considered, where the nonlinear cost based



(a) active power outputs of intermittent DGs.







(c) incremental costs of controllable DGs.

Fig. 7. Case 1: simulation results under the constant total load demand and fluctuating active power outputs of intermittent DGs, when the nonlinear cost based droop scheme is implemented.

droop scheme is implemented. Further, case 3 illustrates the plug and play capability of the nonlinear cost based droop scheme, when both the active power outputs of intermittent

DGs and load demands fluctuate at the same time. Later, the performance of the linear cost based droop scheme is investigated in case 4, which is derived from the quadratic cost function. For case 5, the performance of the linear cost based droop scheme with flat incremental cost and droop curves is investigated. Finally, simulation results are discussed and explained in detail.

In this paper, the distributed secondary voltage control strategy based on local communication among DGs [6], and the decentralized secondary frequency control strategy requiring no communication network are adopted [34], to restore the voltage and frequency to their nominal values, respectively. Note that all simulations are performed in MATLAB/Simulink, where the MG and equations are modeled and solved. In MATLAB/Simulink, it offers blocks for mathematical operation. Based on these blocks, the cost based droop schemes for controllable DGs are modeled, which provides a manner to avoid transmitting signals in or out of MATLAB/Simulink. Moreover, the cost based droop schemes simply require the local information of frequency and power output, while requiring no communication network for information exchanges among DGs. Therefore, the cost based droop schemes can be implemented in an effective manner.

## A. Case 1: Fluctuating Power Outputs of Intermittent DGs

In this case, the nonlinear cost based droop scheme derived from the exponential cost function is implemented. Moreover, the total active load demand remains constant at 155 kW throughout simulations. On the contrary, the active power outputs of intermittent DGs, DG<sub>1</sub>, DG<sub>3</sub>, DG<sub>6</sub>, DG<sub>8</sub> and DG<sub>9</sub> change between 10 kW and 30 kW, because the illumination intensity and wind speed are constantly varying. From Fig. 7(a), it can be seen that the active power outputs of DG<sub>3</sub>, DG<sub>6</sub> and DG<sub>8</sub> decrease gradually, while those of DG<sub>1</sub> and DG<sub>9</sub> remain constant, which follow the changes in environmental conditions at the first three seconds.

Accordingly, the active power outputs of droop-controlled DGs are constantly increasing during this period, so that the generation-load balance is maintained, as illustrated in Fig. 7(b). Moreover, the incremental costs increase with rising active power outputs of controllable DGs, as shown in Fig. 7(c), because the incremental cost is an increasing function of output power. Similarly, from t = 3 s to t = 5 s, the lower the outputs of the controllable DGs, the smaller are the incremental costs.

Furthermore, from Fig. 7(c), it can be found that despite of fluctuations of power outputs of intermittent DGs, the equality of incremental costs among controllable DGs is assured by the nonlinear cost based droop scheme, for equations in (22) are always satisfied. In other words, the equal incremental cost principle is satisfied, and the minimum active power generation cost of the MG is achieved.

### B. Case 2: Time-Varying Load Demands

In this case, the controllable DGs are regulated in terms of the nonlinear cost based droop scheme. And it is assumed that active power outputs of all intermittent DGs are always at



(c) incremental costs of controllable DGs.

Fig. 8. Case 2: simulation results under the constant active power outputs of intermittent DGs and fluctuating load demands, when the nonlinear cost based droop scheme is implemented.

50% of their respective power ratings. On the contrary, large changes in active load demands are scheduled as follows,

• t = 3 s: all active power loads decrease by 15%;

- t = 6 s: all active power loads decrease by 15%;
- t = 8 s: all active power loads increase by 25%,

where the fluctuations of the total active load demand are illustrated in Fig. 8(a).

Under these settings, the total load demand is decreased significantly at t = 3 s by 23.25 kW from 155 kW to 131.75 kW, therefore, the active power outputs of all controllable DGs decrease simultaneously, fulfilling the generationdemand equality constraint in the MG, as shown in Fig. 8(b). Moreover, the incremental costs of controllable DGs drop from 0.47 to 0.43 together, due to lower power outputs, as illustrated in Fig. 8(c). Furthermore, a horizontal line corresponding to the incremental cost at 0.43 can be drawn in Fig. 3. Therefore, the levels of active power outputs (p.u.) of controllable DGs can be read from their respective points, which are 0.36, 0.28, 0.42, 0.56, 0.7 for DG<sub>2</sub>, DG<sub>4</sub>, DG<sub>5</sub>, DG<sub>7</sub>, DG<sub>10</sub>, respectively. According to the analysis in Section III, DG<sub>10</sub> is supposed to has the highest level of output power, when controllable DGs operate at the equal incremental cost, and the simulation results are consistent with the discussion. Accordingly, the active power outputs of DG<sub>2</sub>, DG<sub>4</sub>, DG<sub>5</sub>, DG<sub>7</sub>, DG<sub>10</sub> are 16.2 kW, 8.4 kW, 16.8 kW, 25.2 kW, 14 kW, respectively, as shown in Fig. 8(b). Moreover, the analyses are applicable to active power outputs and incremental costs of controllable DGs after t = 3 s.

On the other hand, it is clear from Fig. 8(b) and Fig. 8(c) that our method has a very short settling time about 0.2 s, which makes sense as our method does not require complicated mathematical modeling and computation, while ensuring the rapid convergence of incremental costs. Furthermore, from Fig. 8(c), we know that regardless of large changes in load demands, the incremental costs reach a common value quickly, satisfying the equal incremental cost principle, because equations in (22) are always satisfied. Therefore, the total active power generation cost is minimized.

# C. Case 3: Plug and Play Capability of Nonlinear Cost Based Droop Scheme

In this case, the nonlinear cost based droop scheme is implemented, when both the active power outputs of intermittent DGs and active load demands change at the same time. In addition, five controllable DGs have already reached the optimal states before the plug out of controllable DG<sub>4</sub> at t = 4 s. Considering the power mismatch under the new situations, the remaining controllable DGs have to produce more power to compensate for the amount of power previously generated by  $DG_4$ , as shown in Fig. 9(a). Therefore, there are increases in incremental costs corresponding with rising power outputs of remaining controllable DGs. While the incremental cost of DG<sub>4</sub> drops to 0.17201 during the plug out, for the incremental cost of DG<sub>4</sub> at no-load is 0.17201, as illustrated in Fig. 9(b). Furthermore, at t = 6.5 s, the synchronization strategy is activated and the seamless plug in of DG<sub>4</sub> into the MG is achieved at t = 7.3 s, and the other four controllable DGs reduce their power outputs to accommodate the plug in of DG<sub>4</sub>, as shown in Fig. 9(a).







(c) line voltages and frequency of the MG.

Fig. 9. Case 3: simulation results under the plug and play of  $DG_4$ , when the nonlinear cost based droop scheme is implemented, and both the active power outputs of intermittent DGs and load demands fluctuate simultaneously.

Moreover, it can be found in Fig. 9(b) that the plug out and plug in operations of  $DG_4$  do not degrade the convergence of the incremental costs, for the equations in (22) are

45

0

22.5

satisfied regardless of behaviors of  $DG_4$ . Therefore, according to the equal incremental cost principle, the nonlinear cost based droop scheme keeps the total active power generation cost to a minimum. On the other hand, the capability of the droop scheme to meet the requirement for plug and play operation is verified.

Furthermore, Fig. 9(c) shows that the MG frequency stays around the nominal value, namely 50 Hz, in all situations. Also the line voltages of loads are still in a normal range, even if fluctuations occur at t = 3 s, 6 s and 8 s, which satisfy the IEEE Standard 1547 requirements [43].

## D. Case 4: Performance of Linear Cost Based Droop Scheme

In this case, the linear cost based droop scheme derived from the quadratic cost function is adopted, and both the active power outputs of intermittent DGs and active load demands change at the same time. Moreover, the plug and play functionality is tested by disconnecting DG<sub>4</sub> at t = 4 s and reconnecting it at t = 7.2 s. The results obtained under the linear cost based droop scheme are shown in Fig. 10.

From Fig. 10(a), it can be seen that  $DG_7$  always has the lowest level of output power, because it is the most costly DG in the MG and it has the lowest priority generating active power. On the other hand, in terms of (22), even if DG<sub>4</sub> is unplugged, the incremental costs of remaining DGs stay at the same level, i.e., the equal incremental cost principle is satisfied. Therefore, it can be seen in Fig. 10(b) that the proposed method maintains the consensus of the incremental costs of remaining DGs, after DG<sub>4</sub> is unplugged at t = 4 s. While the incremental cost of DG<sub>4</sub> drops to 3.3 during the plug out, for the incremental cost of DG<sub>4</sub> at no-load is 3.3. Similarly, despite the plug in operation of DG<sub>4</sub> at t = 7.2 s, the equations in (22) are fulfilled, and the linear cost based droop scheme quickly drives the incremental costs to a consensus value, as illustrated in Fig. 10(b). Accordingly, plug and play functionality can be realized with the linear cost based droop scheme. Finally, it can be found from Fig. 10(c) that the voltages and frequency of the MG are regulated to be within the IEEE Standard limits.

## E. Case 5: Performance of Linear Cost Based Droop Scheme With Flat Incremental Cost Curve

In this case, the linear cost based droop scheme derived from the quadratic cost function is adopted, and  $DG_{10}$  with the power rating of 40 kW and flat incremental cost curve, i.e., constant incremental cost of 4.8 is considered. The incremental cost curves and corresponding cost based droop curves are illustrated in Fig. 11 and Fig. 12, respectively. Moreover, in this case, other settings for the control model follow those in Case 4, and the simulation results are shown in Fig. 13.

In the steady state, DGs share a single common frequency, and we have

$$\frac{\partial C_2(P_2)}{\partial P_2} = \frac{\partial C_4(P_4)}{\partial P_4} = \frac{\partial C_5(P_5)}{\partial P_5} = \frac{\partial C_7(P_7)}{\partial P_7}$$
$$= \lambda_{10} = 0.48. \tag{26}$$



(c) line voltages and frequency of the MG.

Fig. 10. Case 4: simulation results under the plug and play of  $DG_4$ , when the linear cost based droop scheme is implemented, and both the active power outputs of intermittent DGs and load demands fluctuate simultaneously.

In terms of (24) and (26), the power outputs of  $DG_2$ ,  $DG_4$ ,  $DG_5$  and  $DG_7$  remain constant at 19 kW, 8.9 kW, 10.8 kW and 4.8 kW, respectively, when DGs are plugged into the MG,



Fig. 11. Incremental cost curves of DGs with a flat incremental cost curve.



Fig. 12. Linear cost based droop scheme with a flat droop curve.

as shown in Fig. 13(a). On the other hand, the power output of  $DG_{10}$  is constantly varying to maintain the generation-load balance in the MG, and  $DG_{10}$  is turned off at very low-load condition, and it turns on when the total active load demand of the MG increases significantly. Therefore, it can be found in Fig. 13(a) that  $DG_{10}$  is turned off from t = 6.8 s to t = 8 s when the MG is at very low-load condition.

Furthermore, the incremental costs among DGs is maintained around 4.8, as shown in Fig. 13(b), and the decentralized secondary frequency control results in the slight deviation between the incremental cost of DG<sub>10</sub> and those of other DGs. Therefore, the total active power generation cost of the MG is minimized.

## V. CONCLUSION

In this paper, the linear and nonlinear cost based droop schemes are developed, to minimize the total active power generation cost of the islanded MG in a decentralized manner. By embedding the incremental costs into the droop schemes, the proposed cost based droop schemes are able to drive the incremental costs of DGs to a consensus value, minimizing the total active power generation cost of the islanded MG, in terms of the equal incremental cost principle. Finally, the expected minimization of the total active power generation cost, and



(a) active power outputs of controllable DGs.



Fig. 13. Case 5: simulation results with the flat incremental cost curve, when the linear cost based droop scheme is implemented, and both the active power

outputs of intermittent DGs and load demands fluctuate simultaneously.

the capability of plug and play are verified by numerical simulations, in the presence of a high penetration of intermittent renewable energy sources, and large changes in load demands.

On the other hand, the following observations are also worth noting about our method. Firstly, in this paper, we restrict ourselves in an islanded MG, where the MG has already reached the optimal state before the plug out and plug in of a DG. However, when a DG is newly installed in the MG, the cost based droop schemes can be tuned in terms of the given method, which is easy to implement in practice. Secondary, our method is based on droop control, while the intermittent renewable energy sources usually operate in the manner of MPPT rather than droop control, therefore, our method is not applicable to intermittent DGs.

For future work, the proposed method can be refined by considering the generation cost of intermittent renewable energy sources, the vigorous stability analysis of the control model, and the verification of our method on real time experimental platform.

#### ACKNOWLEDGMENT

The authors would like to thank the editors and the reviewers for their insightful comments and suggestions.

## REFERENCES

- D. Abbott, "Keeping the energy debate clean: How do we supply the world's energy needs?" *Proc. IEEE*, vol. 98, no. 1, pp. 42–66, Jan. 2010.
- [2] R. H. Lasseter, "Smart distribution: Coupled microgrids," Proc. IEEE, vol. 99, no. 6, pp. 1074–1082, Jun. 2011.
- [3] J. M. Guerrero, M. Chandorkar, T.-L. Lee, and P. C. Loh, "Advanced control architectures for intelligent microgrids—Part I: Decentralized and hierarchical control," *IEEE Trans. Ind. Electron.*, vol. 60, no. 4, pp. 1254–1262, Apr. 2013.
- [4] D. E. Olivares et al., "Trends in microgrid control," IEEE Trans. Smart Grid, vol. 5, no. 4, pp. 1905–1919, Jul. 2014.
- [5] M. Yazdanian and A. Mehrizi-Sani, "Distributed control techniques in microgrids," *IEEE Trans. Smart Grid*, vol. 5, no. 6, pp. 2901–2909, Nov. 2014.
- [6] Q. Shafiee, J. M. Guerrero, and J. C. Vasquez, "Distributed secondary control for islanded microgrids—A novel approach," *IEEE Trans. Power Electron.*, vol. 29, no. 2, pp. 1018–1031, Feb. 2014.
- [7] Q. Shafiee *et al.*, "Robust networked control scheme for distributed secondary control of islanded microgrids," *IEEE Trans. Ind. Electron.*, vol. 61, no. 10, pp. 5363–5374, Oct. 2014.
- [8] A. Bidram, A. Davoudi, F. L. Lewis, and S. S. Ge, "Distributed adaptive voltage control of inverter-based microgrids," *IEEE Trans. Energy Convers.*, vol. 29, no. 4, pp. 862–872, Dec. 2014.
- [9] F. Guo, C. Wen, J. Mao, and Y.-D. Song, "Distributed secondary voltage and frequency restoration control of droop-controlled inverter-based microgrids," *IEEE Trans. Ind. Electron.*, vol. 62, no. 7, pp. 4355–4364, Jul. 2015.
- [10] J. W. Simpson-Porco *et al.*, "Secondary frequency and voltage control of islanded microgrids via distributed averaging," *IEEE Trans. Ind. Electron.*, vol. 62, no. 11, pp. 7025–7038, Nov. 2015.
- [11] L.-Y. Lu and C.-C. Chu, "Consensus-based secondary frequency and voltage droop control of virtual synchronous generators for isolated AC micro-grids," *IEEE J. Emerg. Sel. Topic Circuits Syst.*, vol. 5, no. 3, pp. 443–455, Sep. 2015.
- [12] H. Xin, M. Zhang, J. Seuss, Z. Wang, and D. Gan, "A real-time power allocation algorithm and its communication optimization for geographically dispersed energy storage systems," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 4732–4741, Nov. 2013.
- [13] H. Xin, Z. Lu, Y. Liu, and D. Gan, "A center-free control strategy for the coordination of multiple photovoltaic generators," *IEEE Trans. Smart Grid*, vol. 5, no. 3, pp. 1262–1269, May 2014.
- [14] A. Bidram, A. Davoudi, and F. L. Lewis, "A multiobjective distributed control framework for islanded AC microgrids," *IEEE Trans. Ind. Informat.*, vol. 10, no. 3, pp. 1785–1798, Aug. 2014.
- [15] M. A. Mahmud, M. J. Hossain, H. R. Pota, and A. M. T. Oo, "Robust nonlinear distributed controller design for active and reactive power sharing in islanded microgrids," *IEEE Trans. Energy Convers.*, vol. 29, no. 4, pp. 893–903, Dec. 2014.
- [16] V. Nasirian, Q. Shafiee, J. M. Guerrero, F. L. Lewis, and A. Davoudi, "Droop-free distributed control for AC microgrids," *IEEE Trans. Power Electron.*, vol. 31, no. 2, pp. 1600–1617, Feb. 2016.
  [17] L.-Y. Lu and C.-C. Chu, "Consensus-based droop control synthesis for
- [17] L.-Y. Lu and C.-C. Chu, "Consensus-based droop control synthesis for multiple DICs in isolated micro-grids," *IEEE Trans. Power Syst.*, vol. 30, no. 5, pp. 2243–2256, Sep. 2015.
- [18] I. U. Nutkani, P. C. Loh, and F. Blaabjerg, "Droop scheme with consideration of operating costs," *IEEE Trans. Power Electron.*, vol. 29, no. 3, pp. 1047–1052, Mar. 2014.
- [19] W. Zhang, W. Liu, X. Wang, L. Liu, and F. Ferrese, "Online optimal generation control based on constrained distributed gradient algorithm," *IEEE Trans. Power Syst.*, vol. 30, no. 1, pp. 35–45, Jan. 2015.
- [20] W. Zhang, Y. Xu, W. Liu, C. Zang, and H. Yu, "Distributed online optimal energy management for smart grids," *IEEE Trans. Ind. Informat.*, vol. 11, no. 3, pp. 717–727, Jun. 2015.
- [21] Y. Xu, W. Zhang, and W. Liu, "Distributed dynamic programmingbased approach for economic dispatch in smart grids," *IEEE Trans. Ind. Informat.*, vol. 11, no. 1, pp. 166–175, Feb. 2015.

- [22] Y. Xu, Z. Yang, W. Gu, M. Li, and Z. Deng, "Robust real-time distributed optimal control based energy management in a smart grid," *IEEE Trans. Smart Grid*, to be published, doi: 10.1109/TSG.2015.2491923.
- [23] G. Binetti, A. Davoudi, F. L. Lewis, D. Naso, and B. Turchiano, "Distributed consensus-based economic dispatch with transmission losses," *IEEE Trans. Power Syst.*, vol. 29, no. 4, pp. 1711–1720, Jul. 2014.
- [24] Z. Zhang and M.-Y. Chow, "Convergence analysis of the incremental cost consensus algorithm under different communication network topologies in a smart grid," *IEEE Trans. Power Syst.*, vol. 27, no. 4, pp. 1761–1768, Nov. 2012.
- [25] S. Yang, S. Tan, and J.-X. Xu, "Consensus based approach for economic dispatch problem in a smart grid," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 4416–4426, Nov. 2013.
- [26] N. Rahbari-Asr, U. Ojha, Z. Zhang, and M.-Y. Chow, "Incremental welfare consensus algorithm for cooperative distributed generation/demand response in smart grid," *IEEE Trans. Smart Grid*, vol. 5, no. 6, pp. 2836–2845, Nov. 2014.
- [27] V. Loia and A. Vaccaro, "Decentralized economic dispatch in smart grids by self-organizing dynamic agents," *IEEE Trans. Syst., Man, Cybern., Syst.*, vol. 44, no. 4, pp. 397–408, Apr. 2014.
- [28] G. Chen, F. L. Lewis, E. N. Feng, and Y. Song, "Distributed optimal active power control of multiple generation systems," *IEEE Trans. Ind. Electron.*, vol. 62, no. 11, pp. 7079–7090, Nov. 2015.
- [29] G. Binetti, A. Davoudi, D. Naso, B. Turchiano, and F. L. Lewis, "A distributed auction-based algorithm for the nonconvex economic dispatch problem," *IEEE Trans. Ind. Informat.*, vol. 10, no. 2, pp. 1124–1132, May 2014.
- [30] Y. Xu and Z. Li, "Distributed optimal resource management based on the consensus algorithm in a microgrid," *IEEE Trans. Ind. Electron.*, vol. 62, no. 4, pp. 2584–2592, Apr. 2015.
- [31] F. Guo, C. Wen, J. Mao, and Y.-D. Song, "Distributed economic dispatch for smart grids with random wind power," *IEEE Trans. Smart Grid*, vol. 7, no. 3, pp. 1572–1583, May 2016.
- [32] Z. Wang, W. Wu, and B. Zhang, "A fully distributed power dispatch method for fast frequency recovery and minimal generation cost in autonomous microgrids," *IEEE Trans. Smart Grid*, vol. 7, no. 1, pp. 19–31, Jan. 2016.
- [33] H. Xin, L. Zhang, Z. Wang, D. Gan, and K. P. Wong, "Control of island AC microgrids using a fully distributed approach," *IEEE Trans. Smart Grid*, vol. 6, no. 2, pp. 943–945, Mar. 2015.
- [34] H. Xin *et al.*, "A decentralized hierarchical control structure and selfoptimizing control strategy for F-P type DGs in islanded microgrids," *IEEE Trans. Smart Grid*, vol. 7, no. 1, pp. 3–5, Jan. 2016.
- [35] I. U. Nutkani, P. C. Loh, and F. Blaabjerg, "Cost-based droop scheme with lower generation costs for microgrids," *IET Power Electron.*, vol. 7, no. 5, pp. 1171–1180, May 2014.
- [36] I. U. Nutkani, P. C. Loh, P. Wang, and F. Blaabjerg, "Autonomous droop scheme with reduced generation cost," *IEEE Trans. Ind. Electron.*, vol. 61, no. 12, pp. 6803–6811, Dec. 2014.
- [37] I. U. Nutkani, P. C. Loh, P. Wang, and F. Blaabjerg, "Cost-prioritized droop schemes for autonomous AC microgrids," *IEEE Trans. Power Electron.*, vol. 30, no. 2, pp. 1109–1119, Feb. 2015.
- [38] I. U. Nutkani, P. C. Loh, P. Wang, and F. Blaabjerg, "Decentralized economic dispatch scheme with online power reserve for microgrids," *IEEE Trans. Smart Grid*, to be published, doi: 10.1109/TSG.2015.2451133.
- [39] I. U. Nutkani, P. C. Loh, P. Wang, and F. Blaabjerg, "Linear decentralized power sharing schemes for economic operation of AC microgrids," *IEEE Trans. Ind. Electron.*, vol. 63, no. 1, pp. 225–234, Jan. 2016.
- [40] Y. Xu, W. Zhang, G. Hug, S. Kar, and Z. Li, "Cooperative control of distributed energy storage systems in a microgrid," *IEEE Trans. Smart Grid*, vol. 6, no. 1, pp. 238–248, Jan. 2015.
- [41] J. M. Guerrero, J. C. Vasquez, J. Matas, L. G. D. Vicuña, and M. Castilla, "Hierarchical control of droop-controlled AC and DC microgrids— A general approach toward standardization," *IEEE Trans. Ind. Electron.*, vol. 58, no. 1, pp. 158–172, Jan. 2011.
- [42] J. C. Vasquez, J. M. Guerrero, J. Miret, M. Castilla, and L. G. D. Vicuña, "Hierarchical control of intelligent microgrids," *IEEE Ind. Electron. Mag.*, vol. 4, no. 4, pp. 23–29, Dec. 2010.
- [43] T. S. Basso and R. DeBlasio, "IEEE 1547 series of standards: Interconnection issues," *IEEE Trans. Power Electron.*, vol. 19, no. 5, pp. 1159–1162, Sep. 2004.



**Feixiong Chen** received the B.S. degree in electrical engineering from the Chongqing University of Technology, Chongqing, China, in 2012. He is currently pursuing the Ph.D. degree with the School of Electrical Engineering, Chongqing University, Chongqing.

His current research interests include distributed control and optimization of microgrids.



**Minyou Chen** (M'05–SM'14) received the M.Sc. degree in control theory and engineering from Chongqing University, China, in 1987, and the Ph.D. degree in control engineering from the University of Sheffield, Sheffield, U.K., in 1998.

He is currently a Full Professor with Chongqing University. His current research interests include intelligent modeling and control, multiobjective optimization, microgrid control, and state monitoring in power distribution systems. He has authored or co-authored over 180 papers.



**Qiang Li** received the B.S. degree in electrical engineering from the Sichuan Institute of Technology, China, in 2001, the M.S. degree in control theory and engineering from Chongqing University, China, in 2004, and the Ph.D. degree in electrical engineering from Zhejiang University, China, in 2009.

He was a Post-Doctoral Fellow with Chongqing University, from 2009 to 2012, and a Visiting Post-Doctoral Scholar with the University of Adelaide, Adelaide, SA, Australia, from 2011 to 2012. He was a Visiting Post-Doctoral Scholar with Boston

University, Boston, MA, USA, from 2014 to 2015. He is currently an Associate Professor with Chongqing University. His current research interests include networked control systems, optimization of microgrids, evolutionary dynamics, and quantum games.



Kaikai Meng received the B.S. degree in applied physics from Chongqing University, Chongqing, China, in 2012, and the M.S. degree in electrical engineering from the School of Electrical Engineering, Chongqing University, Chongqing, in 2015.

She is currently with the Fuzhou Power Supply Company of State Grid Fujian Electric Power Company, Fujian, China, where she is engaged with the operation and control of power system.



Yongwei Zheng received the B.S. degree in electrical engineering from the Sichuan Institute of Technology, Chongqing, China, in 2010, and the M.S. degree from the School of Electrical Engineering, Chongqing University, Chongqing, in 2013.

He is currently an Engineer with the Neijiang Electric Power Supply Company of State Grid Sichuan Electric Power Company, Sichuang, China. His current research interests include operation and control of power system.



Josep M. Guerrero (S'01–M'04–SM'08–F'15) received the B.S. degree in telecommunications engineering, the M.S. degree in electronics engineering, and the Ph.D. degree in power electronics from the Technical University of Catalonia, Barcelona, in 1997, 2000, and 2003, respectively. Since 2011, he has been a Full Professor with the Department of Energy Technology, Aalborg University, Denmark, where he is responsible for the Microgrid Research Program. Since 2012, he has been a Guest Professor with the Chinese Academy of Science and the

Nanjing University of Aeronautics and Astronautics. Since 2014, he has been the Chair Professor with Shandong University, and since 2015, he has been a Distinguished Guest Professor with Hunan University.

His research interests are oriented to different microgrid aspects, including power electronics, distributed energy-storage systems, hierarchical and cooperative control, energy management systems, optimization of microgrids and islanded microgrids, maritime microgrids for electrical ships, vessels, ferries, and seaports. He was a recipient of the Best Paper Award of the IEEE TRANSACTIONS ON ENERGY CONVERSION from 2014 to 2015 and the Highly Cited Researcher Award from Thomson Reuters, in 2014 and 2015. He is an Associate Editor of the IEEE TRANSACTIONS ON POWER ELECTRONICS, the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS, and the IEEE Industrial Electronics Magazine, and an Editor of the IEEE TRANSACTIONS ON SMART GRID and IEEE TRANSACTIONS ON ENERGY CONVERSION. He has been a Guest Editor of the IEEE TRANSACTIONS ON POWER ELECTRONICS Special Issues on Power Electronics for Wind Energy Conversion and Power Electronics for Microgrids, the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS Special Sections on Uninterruptible Power Supplies systems, Renewable Energy Systems, Distributed Generation and Microgrids, and Industrial Applications and Implementation Issues of the Kalman Filter, and the IEEE TRANSACTIONS ON SMART GRID Special Issue on Smart DC Distribution Systems. He was the Chair of the Renewable Energy Systems Technical Committee of the IEEE Industrial Electronics Society.



**Derek Abbott** (M'85–SM'99–F'05) was born in South Kensington, London, U.K., in 1960. He received the B.Sc. (Hons.) degree in physics from Loughborough University, Leicestershire, U.K., in 1982, and the Ph.D. degree in electrical and electronic engineering from the University of Adelaide, Adelaide, SA, Australia, in 1995, under the supervision of K. Eshraghian and B. R. Davis. From 1978 to 1986, he was a Research Engineer with the GEC Hirst Research Centre, London, U.K. From 1986 to 1987, he was a VLSI Design Engineer with

Austek Microsystems, Australia. Since 1987, he has been with the University of Adelaide, where he is currently a Full Professor with the School of Electrical and Electronic Engineering. He holds over 800 publications/patents and has been an invited speaker at over 100 institutions. He co-edited the book entitled Quantum Aspects of Life (London, U.K.: Imperial College Press, 2008) and co-authored the books entitled Stochastic Resonance, (Cambridge, U.K.: Cambridge Univ. Press, 2008) and Terahertz Imaging for Biomedical Applications, (New York, NY, USA: Springer-Verlag, 2012). His interest is in the area of multidisciplinary physics and electronic engineering applied to complex systems. His research programs span a number of areas including networks, game theory, energy policy, stochastics, and biophotonics. He was a recipient of the number of awards, including the South Australian Tall Poppy Award for Science in 2004, an Australian Research Council Future Fellowship in 2012, and the David Dewhurst Medal, Australia, in 2015. He has served as an Editor and/or a Guest Editor for a number of journals, including the IEEE JOURNAL OF SOLID-STATE CIRCUITS, the Journal of Optics B, Microelectronics Journal, PLoSOne, PROCEEDINGS OF THE IEEE, and the IEEE PHOTONICS JOURNAL. He is currently an Editorial Board Member of Nature's Scientific Reports, Royal Society Open Science, and the IEEE ACCESS. He is a fellow of the Institute of Physics.