

Optimal allocation of series FACTS devices in large-scale systems

ISSN 1751-8687

Received on 6th August 2017

Revised 11th December 2017

Accepted on 20th December 2017

E-First on 21st February 2018

doi: 10.1049/iet-gtd.2017.1223

www.ietdl.org

Xiaohu Zhang¹ ✉, Kevin Tomsovic¹, Aleksandar Dimitrovski²¹Department of Electrical Engineering and Computer Science, The University of Tennessee, Knoxville, TN 37996, USA²Department of Electrical and Computer Engineering, University of Central Florida, FL 32816, USA

✉ E-mail: xzhang46@vols.utk.edu

Abstract: Series flexible AC transmission systems devices, such as the variable series reactor, have the ability to continuously regulate the transmission line reactance so as to control power flow. This study presents a new approach to optimally locating such devices in the transmission network considering multiple operating states and contingencies. To investigate optimal investment, a single target year planning with three different load patterns is considered. The transmission contingencies may occur under any of the three load conditions and the coupling constraints between base case and contingencies are included. A reformulation technique transforms the original mixed integer non-linear programming model into mixed integer linear programming model. To further relieve the computational burden and enable the planning model to be directly applied to practical large-scale systems, a two-phase decomposition algorithm is introduced. Detailed numerical simulation results on IEEE 118-bus system and the Polish 2383-bus system illustrate the efficient performance of the proposed algorithm.

Nomenclature

Indices

i, j	index of buses
k	index of transmission elements
n	index of generators
m	index of loads
c	index of states; $c = 0$ indicates the base case; $c > 0$ is a contingency state
t	index of load levels

Variables

P_{nct}^g	active power generation of generator n for state c at load level t
P_{kct}	active power flow on branch k for state c at load level t
x_k^V	reactance of a VSR at branch k
θ_{kct}	the angle difference across the branch k for state c at load level t
δ_k	binary variable associated with installing a VSR on branch k
$\Delta P_{nct}^{g,up}$	active power generation adjustment up of generator n for state c at load level t
$\Delta P_{nct}^{g,dn}$	active power generation adjustment down of generator n for state c at load level t
ΔP_{mct}^d	load shedding quantity of load m for state c at load level t

Parameters

a_n^g	cost coefficient for generator n
$a_n^{g,up}$	cost coefficient for generator n to increase active power
$a_n^{g,dn}$	cost coefficient for generator n to decrease active power
a_{LS}	penalty for the load shedding
A_h	annual operating hours: 8760 h
A_I	annual investment cost for VSR
N_{kct}	binary parameter associated with the status of branch k for state c at load level t
θ_k^{\max}	maximum angle difference across branch k : $\pi/3$ radians
$P_{nct}^{g,\min}$	minimum active power output of generator n for state c at load level t

$P_{nct}^{g,\max}$	maximum active power output of generator n for state c at load level t
P_{mct}^d	active power consumption of demand m for state c at load level t
S_{kct}^{\max}	thermal limit of branch k for state c at load level t
$R_n^{g,up}$	ramp up limit of generator n
$R_n^{g,dn}$	ramp down limit of generator n
π_{ct}	duration of state c at load level t

Sets

\mathcal{B}	set of buses
\mathcal{B}_{ref}	set of reference bus
Ω_L	set of transmission lines
Ω_L^i	set of transmission lines connected to bus i
\mathcal{G}	set of on-line generators
\mathcal{G}_i	set of on-line generators located at bus i
\mathcal{G}_{re}	set of on-line generators that allow to rescheduling
\mathcal{D}	set of loads
\mathcal{D}_i	set of loads located at bus i
Ω_0	set of base operating states
Ω_c	set of contingency operating states
Ω_V	set of candidate transmission lines to install VSR
Ω_T	set of load levels

1 Introduction

Due to the power market restructuring and the rapid introduction of renewables, the electric power industry is going through profound changes across technical, economic and organisational concerns. While deregulation has been able to deliver on some promises, such as the reduction in electricity prices and new innovative technologies to improve the grid efficiency, it has also led to strains on the transmission system, which was not designed for this new structure. Increasing electricity consumption, less predictable power flows and extensive adoption of renewable energy have led to increasing power grid congestion [1]. One option to relieve congestion in the transmission network is through power system expansion, which involves building new power plants and transmission lines in critical areas. This option suffers from the




Fig. 1 Steady-state model of VSR in DCPF

difficulties in obtaining right-of-way, high cost and long construction times. An alternative to increase the effective transmission capability is by installing the power flow control devices such as the flexible AC transmission systems (FACTS) in the existing network [2–4].

A series FACTS controller, variable series reactor (VSR), has the ability to vary the effective transmission line reactance so it is suitable for power flow control. Increasing the impedance on the congested lines can shift power to underutilised transmission lines nearby while decreasing the impedance of the transmission line can increase power transferred on that line assuming thermal limits have not been reached. With the rapid developments in the power electronics technology, VSR offers excellent control and flexibility. Moreover, according to the green electricity network integration programme [5], it is anticipated that there will be new FACTS-like devices with far cheaper cost [6] available to be installed in the transmission network across US in the future. Given these considerations, efficient planning models and algorithms, which directly work for practical large-scale systems, should be developed to provide an optimal planning for the application of FACTS devices.

The allocation and utilisation of FACTS devices has been studied extensively during the last several decades. Considering the non-linear and non-convex characteristics of the power flow equations, different heuristic approaches such as differential evolution [7], genetic algorithm [8–11], particle swarm optimisation (PSO) [12, 13] have been leveraged to optimally allocate FACTS devices. Priority indices are another class of methods for locating FACTS devices. To decide the optimal locations of thyristor controlled series compensator (TCSC), the authors in [14] define the priority indices as the weighted sensitivities of the system transfer capability with respect to each line reactance. In [15], the difference of locational marginal price (LMP) across a transmission line is computed with a standard optimal power flow problem. The locations of TCSC are determined based on the magnitudes of the LMP difference. A main drawback of the priority indices methods is that the quality of the solution regarding optimality cannot be guaranteed.

With rapid advances in mathematical programming algorithms, these methods have been widely used to analyse the impacts of FACTS devices. The authors in [16] leverage line flow-based equations proposed in [17] to determine the locations and compensation levels of TCSC via mixed integer linear programming (MILP) and mixed integer quadratic programming. To linearise the product of two continuous variables in the constraints, one variable in the product is relaxed by its upper and lower bound. In addition, only one load pattern is considered so the planning model is suitable for preliminary analysis. In [18], the branch and price algorithm is utilised to co-optimize the locations of transmission switch and TCSC considering the wind power uncertainties. In [19, 20], Benders decomposition is used to investigate the benefits of VSR devices in the security constrained optimal power flow problem. The master problem is to minimise the generation cost with the pre-located FACTS devices and the subproblem is used to check the feasibility for each contingency. To include VSR in the economic dispatch problem, researchers have reformulated the non-linear programming model into an MILP model [21, 22].

The authors in [23] demonstrate that with appropriately installed TCSC and static VAR compensator (SVC) in the power network, the operation cost during contingencies can be reduced. Hence, from the planning point of view, including the contingency constraints in FACTS placement model could provide a more accurate and useful investment strategy for the system planners. However, the task is not trivial since adding contingency constraints increases the model size significantly and leads to

excessive computational burdens. The authors in [24, 25] adopt the two-level hybrid PSO/SQP algorithm to address this problem but the computation burden is large for a small- or medium-scale system.

This paper proposes a new solution approach to optimally allocate VSR in large-scale transmission networks considering the base case and a series of $N - 1$ transmission contingencies. We consider a single target year for the planning. Three distinct load levels which denote peak, normal and low load conditions are selected. The original planning model is a large-scale mixed integer non-linear programming (MINLP) model which is difficult to solve for practical systems. A reformulation technique is used to transform the MINLP model into an MILP model. To further relieve the computational burden, a two-phase Benders decomposition separates the problem into base case master problem and a series of subproblems for contingencies. Considering the extensive literature in this area, the contributions of this paper are twofold:

- i. to develop a planning model to allocate VSR in the transmission network considering a multi-scenario framework and solve the model using mathematical programming rather than the heuristic or sensitivity methods so that the quality of the solution can be ensured;
- ii. to implement a two-phase Benders decomposition for the planning problem which shows high performance even for a practical large-scale network considering hundreds of operating conditions.

The remaining sections are organised as follows: Section 2 illustrates the reformulation technique. The detailed optimisation model is given in Section 3. In Section 4, the solution procedure based on Benders decomposition is described. The IEEE 118-bus system and Polish 2383-bus system are selected for case studies in Section 5. Finally, conclusions are given in Section 6.

2 Reformulation technique

We leverage the reformulation technique proposed in [26, 27] to linearise the non-linear power flow equations due to the introduction of VSR. The procedures are illustrated in this section for completeness.

The static model of a VSR in DC power flow is depicted in Fig. 1. It can be denoted by a variable reactance x_k^V in series with the line reactance x_k .

The resulting susceptance of the transmission line \tilde{b}_k can be expressed as

$$\tilde{b}_k = -\frac{1}{x_k + x_k^V} = -(b_k + b_k^V) \quad (1)$$

In (1), b_k can be interpreted as the negative susceptance of line k without VSR and b_k^V is the susceptance change introduced by the VSR. Their expressions are given as

$$b_k = \frac{1}{x_k} \quad (2)$$

$$b_k^V = -\frac{x_k^V}{x_k(x_k + x_k^V)} \quad (3)$$

The active power transferred on transmission line k is:

$$P_k = (b_k + \delta_k b_k^V)\theta_k \quad (4)$$

$$b_{k,V}^{\min} \leq b_k^V \leq b_{k,V}^{\max} \quad (5)$$

The binary variable δ_k is introduced to indicate the installation of a VSR on the transmission line.

In (4), the non-linear term is $\delta_k b_k^V \theta_k$. To linearise the non-linear term, a dummy variable ψ_k is first introduced:

$$\psi_k = \delta_k b_k^V \theta_k \quad (6)$$

Then the power flow (4) can be rewritten as

$$P_k = b_k \theta_k + \psi_k \quad (7)$$

and we multiply δ_k with each side of the constraint (5) to obtain:

$$\delta_k b_{k,V}^{\min} \leq \frac{\psi_k}{\theta_k} = \delta_k b_k^V \leq \delta_k b_{k,V}^{\max} \quad (8)$$

The allowable range of ψ_k is dependent on the sign of the phase angle difference across transmission line k , i.e. θ_k . We introduce a binary variable y_k and use the big-M complementary constraints to linearise (8):

$$-M_k y_k + \delta_k \theta_k b_{k,V}^{\min} \leq \psi_k \leq \delta_k \theta_k b_{k,V}^{\max} + M_k y_k \quad (9)$$

$$-M_k (1 - y_k) + \delta_k \theta_k b_{k,V}^{\max} \leq \psi_k \leq \delta_k \theta_k b_{k,V}^{\min} + M_k (1 - y_k) \quad (10)$$

The physical interpretation of y_k is the flow direction of transmission element k . Note that only one of the two constraints (9) and (10) will be active during the optimisation process and the other one will be always satisfied because of the large number M_k .

In constraints (9) and (10), there still exists a bilinear term $\delta_k \theta_k$ which is the product of a continuous variable and a binary variable. Another variable $v_k = \delta_k \theta_k$ is introduced and linearised by using the big-M method [28]:

$$-\delta_k \theta_k^{\max} \leq v_k \leq \delta_k \theta_k^{\max} \quad (11)$$

$$\theta_k - (1 - \delta_k) \theta_k^{\max} \leq v_k \leq \theta_k + (1 - \delta_k) \theta_k^{\max} \quad (12)$$

Finally, the constraints (9) and (10) can be rewritten as (13) and (14) by replacing $\delta_k \theta_k$ with v_k :

$$-M_k y_k + v_k b_{k,V}^{\min} \leq \psi_k \leq v_k b_{k,V}^{\max} + M_k y_k \quad (13)$$

$$-M_k (1 - y_k) + v_k b_{k,V}^{\max} \leq \psi_k \leq v_k b_{k,V}^{\min} + M_k (1 - y_k) \quad (14)$$

Therefore, the non-linear power flow equations (4) and (5) are reformulated into an MILP format including (7), (11)–(14).

3 Problem formulation

With the reformulation, the complete optimisation model can be represented as a large-scale MILP.

3.1 Objective function

The objective of the proposed planning model is to minimise the total cost for the single target year, which can be formulated as

$$\min_{\Xi_{\text{OM}}} \sum_{k \in \Omega_V} A_I \delta_k + \sum_{t \in \Omega_T} (\pi_{ot} C_{ot} + \sum_{c \in \Omega_c} \pi_{ct} C_{ct}) \quad (15)$$

There are three components in the objective function (15). Specifically, the first term denotes the annualised investment cost in VSR; the second and third terms represent the operation cost under base and contingency states, respectively. Under load level t , the operation cost for the base state, i.e. C_{ot} , can be further expressed as

$$C_{ot} = \sum_{n \in \mathcal{G}} a_n^g P_{not}^g \quad (16)$$

The operation cost under the contingency state c and load level t comprises four terms:

$$C_{ct} = \sum_{n \in \mathcal{G}} a_n^g P_{nct}^g + \sum_{m \in \mathcal{D}} a_{LS} \Delta P_{mct}^d + \sum_{n \in \mathcal{G}} (a_n^{g,up} \Delta P_{nct}^{g,up} + a_n^{g,dn} \Delta P_{nct}^{g,dn}) \quad (17)$$

The generation cost under each contingency is indicated by the first term; the load shedding cost is denoted by the second term; the generator up and down adjustment costs are represented by the third and fourth terms, respectively. Each operating state is associated with a duration time π_{ct} so the cost for the individual state is appropriately weighted. Note that the number of operation hours for a target year is 8760, which is given as

$$\sum_{t \in \Omega_T} \pi_{ot} + \sum_{t \in \Omega_T} \sum_{c \in \Omega_c} \pi_{ct} = A_h \quad (18)$$

3.2 Constraints

The complete set of constraints are given as

$$P_{kct} = N_{kct} b_k \theta_{kct}, \quad k \in \Omega_L \setminus \Omega_V \quad (19)$$

$$P_{kct} = N_{kct} (b_k \theta_{kct} + \psi_{kct}), \quad k \in \Omega_V \quad (20)$$

$$-M_k y_{kct} + v_{kct} b_{k,V}^{\min} \leq \psi_{kct} \leq v_{kct} b_{k,V}^{\max} + M_k y_{kct}, \quad k \in \Omega_V \quad (21)$$

$$-M_k (1 - y_{kct}) + v_{kct} b_{k,V}^{\max} \leq \psi_{kct} \leq v_{kct} b_{k,V}^{\min} + M_k (1 - y_{kct}), \quad k \in \Omega_V \quad (22)$$

$$-\delta_k \theta_k^{\max} \leq v_{kct} \leq \delta_k \theta_k^{\max}, \quad k \in \Omega_V \quad (23)$$

$$\theta_{kct} - (1 - \delta_k) \theta_k^{\max} \leq v_{kct} \leq \theta_{kct} + (1 - \delta_k) \theta_k^{\max}, \quad k \in \Omega_V \quad (24)$$

$$\sum_{n \in \mathcal{G}_i} P_{nct}^g - \sum_{m \in \mathcal{D}_i} (P_{mct}^d - \Delta P_{mct}^d) = \sum_{k \in \Omega_L^i} P_{kct} \quad (25)$$

$$-S_{kct}^{\max} \leq P_{kct} \leq S_{kct}^{\max}, \quad k \in \Omega_L \quad (26)$$

$$P_{nct}^{g,\min} \leq P_{nct}^g \leq P_{nct}^{g,\max} \quad (27)$$

$$\theta_i = 0, \quad i \in \mathcal{B}_{\text{ref}} \quad (28)$$

$$P_{nct}^g = P_{not}^g + \Delta P_{nct}^{g,up} - \Delta P_{nct}^{g,dn}, \quad n \in \mathcal{G}_{\text{re}} \quad (29)$$

$$0 \leq \Delta P_{nct}^{g,up} \leq R_n^{g,up}, \quad n \in \mathcal{G}_{\text{re}} \quad (30)$$

$$0 \leq \Delta P_{nct}^{g,dn} \leq R_n^{g,dn}, \quad n \in \mathcal{G}_{\text{re}} \quad (31)$$

$$P_{nct}^g = P_{not}^g, \quad n \in \mathcal{G} \setminus \mathcal{G}_{\text{re}} \quad (32)$$

$$0 \leq \Delta P_{mct}^d \leq P_{mct}^d \quad (33)$$

Constraints (19)–(24), (26)–(28) hold $\forall c \in \Omega_c \cup \Omega_0, t \in \Omega_T, n \in \mathcal{G}$, constraints (25) hold $\forall c \in \Omega_c \cup \Omega_0, t \in \Omega_T, i \in \mathcal{B}$, and constraints (29)–(33) hold $\forall c \in \Omega_c, t \in \Omega_T, m \in \mathcal{D}$.

Constraints (19)–(28) are the operating constraints, including base case and contingencies. Specifically, constraint (19) is the power flow on the lines without VSR and constraint (20) represents the power flow on the candidate lines to install VSR. We introduce a binary parameter N_{kct} to denote the corresponding status of the transmission element k in state c at load level t [29]. If $N_{kct} = 1$, the line flow equations are forced to hold; otherwise, if the line is in outage, the power flow on that line is forced to be zero. The reformulation considering multiple operating states and load levels is denoted by constraints (21)–(24). Constraint (25) ensures the

power balance at each bus. The thermal limits of the transmission lines and the active power limits of the generators are considered in (26) and (27). Note that the short-term rating for the transmission line is used for the contingency states, which is 10% higher than the thermal limit under the base operating condition. Finally, constraint (28) sets the bus angle of the reference bus to zero.

Constraints (29)–(33) denote limits under the contingency states. Constraints (29)–(32) indicate that only a subset of generators are allowed to redispatch their generation during the contingencies and all the other generators should be fixed at their base operating condition. The load shedding quantity should not exceed the existing load, which is given in (33).

The optimisation variables of the complete planning model from (15)–(33) are the elements in set $\Xi_{OM} = \{\theta_{kct}, P_{kct}, P_{nct}^g, \Delta P_{mct}^d, \Delta P_{nct}^{g,up}, \Delta P_{nct}^{g,dn}, \delta_k, y_{kct}, v_{kct}, \psi_{kct}\}$.

4 Solution approach

The size of the MILP model formulated in Section 3 dramatically increases with the system size and the number of considered contingencies, which leads to excessive computation. In order to make the optimisation model applicable to a practical large system, Benders decomposition is used to decompose the original optimisation model into a master problem and a subproblem. The master problem deals with the base operating condition and the subproblem considers contingencies. The complicating variables between the master problem and subproblem are P_{not}^g and δ_k .

It should be noted that the prerequisite for Benders decomposition is that the objective function of the considered problem projected on the subspace of the complicating variables has a convex envelope [30]. This is not the case in our model due to the existence of the binary flow direction variable y_{kct} in the subproblem. In [31], a modified Benders decomposition (MBD) is developed for the security constrained unit commitment considering the quick-start units. The main idea is to construct a tighter LP subproblem based on the MILP subproblem and use the tighter LP to generate Benders cuts. We propose an alternative two-phase approach in Section 4.3. The simulation results obtained from the proposed approach and MBD are compared in Section 5.

4.1 Master problem

The master problem considers the base operating condition for the three load levels:

$$\min_{\Xi_{MP}} Z_{down}^{(\nu)} = \sum_{t \in \Omega_T} \pi_{ot} C_{ot}^{(\nu)} + \sum_{k \in \Omega_V} A_I \delta_k^{(\nu)} + \alpha^{(\nu)} \quad (34)$$

$$\text{s. t.} \quad (19) - (28) \text{ and}$$

$$\alpha^{(\nu)} \geq \alpha_{down} \quad (35)$$

$$\alpha^{(\nu)} \geq Z^{(l)} + \sum_{t \in \Omega_T} \sum_{n \in \mathcal{G}} \mu_{nt}^{(l)} (P_{not}^{g(\nu)} - P_{not}^{g(l)}) + \sum_{k \in \Omega_V} \beta_k^{(l)} (\delta_k^{(\nu)} - \delta_k^{(l)}), \quad l = 1, \dots, \nu - 1 \quad (36)$$

Constraints (34)–(36) hold $\forall c \in \Omega_c, t \in \Omega_T, n \in \mathcal{G}, i \in \mathcal{B}$.

The optimisation variables of the master problem are those in the set $\Xi_{MP} = \{\theta_{kct}, P_{kct}, P_{nct}^g, \delta_k, y_{kct}, v_{kct}, \psi_{kct}, \alpha\}$. Note that all the variables are subject to Benders iteration parameter ν . The first and second terms in the objective function are the operating cost in the base case and the investment cost for the VSR. $\alpha^{(\nu)}$ denotes the total operating cost during the contingencies. To accelerate the convergence speed, constraint (35) sets a lower bound on $\alpha^{(\nu)}$. Constraint (36) represents the Benders cut, which will be generated once per iteration.

4.2 Subproblem

The subproblem for contingency state c and load level t is:

$$\min_{\Xi_{SP}} Z_{ct}^{(\nu)} = C_{ct}^{(\nu)} + \sum_{i \in \mathcal{B}} h_i (s_{ict,1}^{(\nu)} + s_{ict,2}^{(\nu)}) \quad (37)$$

$$\text{s. t.} \quad (19) - (24), (26) - (33) \text{ and}$$

$$\sum_{n \in \mathcal{G}_i} P_{nct}^{g(\nu)} - \sum_{m \in \mathcal{D}_i} (P_{mct}^d - \Delta P_{mct}^{d(\nu)}) + s_{ict,1}^{(\nu)} - s_{ict,2}^{(\nu)} = \sum_{k \in \Omega_i} P_{kct}^{(\nu)} \quad (38)$$

$$s_{ict,1}^{(\nu)} \geq 0, \quad s_{ict,2}^{(\nu)} \geq 0 \quad (39)$$

$$P_{not}^{g(\nu)} = \hat{P}_{not}^g: \mu_{nct}^{(\nu)} \quad (40)$$

$$\delta_k^{(\nu)} = \hat{\delta}_k: \beta_{kct}^{(\nu)} \quad (41)$$

Constraints (37)–(41) hold $\forall c \in \Omega_c, t \in \Omega_T, n \in \mathcal{G}, i \in \mathcal{B}, m \in \mathcal{D}$.

The optimisation variables of the subproblem are those in the set $\Xi_{SP} = \{\theta_{kct}, P_{kct}, P_{nct}^g, \Delta P_{mct}^d, \Delta P_{nct}^{g,up}, \Delta P_{nct}^{g,dn}, v_{kct}, y_{kct}, \delta_k, \psi_{kct}, s_{ict,1}, s_{ict,2}\}$

The first term of the objective function is the operating cost in each contingency. Note that although load shedding is allowed in the contingency state, the subproblem can still be infeasible due to generator ramping constraints. Two slack variables $s_{ict,1}^{(\nu)}$ and $s_{ict,2}^{(\nu)}$ are introduced to ensure that the subproblem is feasible with h_i a sufficiently large positive constant. The complicating variables are fixed at the value obtained from the master problem in constraints (40) and (41) while $\mu_{nct}^{(\nu)}$ and $\beta_{kct}^{(\nu)}$ are the dual variables associated with these two constraints.

The sensitivity used to generate Benders cut is the weighted dual variable, which can be expressed as

$$\mu_{nt}^{(\nu)} = \sum_{c \in \Omega_c} \pi_{ct} \mu_{nct}^{(\nu)} \quad (42)$$

$$\beta_k^{(\nu)} = \sum_{c \in \Omega_c} \sum_{t \in \Omega_T} \pi_{ct} \beta_{kct}^{(\nu)} \quad (43)$$

In the master problem, Z in the Benders cut constraint can be calculated as

$$Z^{(\nu)} = \sum_{c \in \Omega_c} \sum_{t \in \Omega_T} \pi_{ct} Z_{ct}^{(\nu)} \quad (44)$$

With the solution of the subproblem, the upper bound of the objective function for the original problem is calculated as

$$Z_{up}^{(\nu)} = Z^{(\nu)} + \sum_{t \in \Omega_T} \pi_{ot} \hat{C}_{ot} + \sum_{k \in \Omega_V} A_I \hat{\delta}_k \quad (45)$$

The last two terms in (45) are calculated using the fixed value of \hat{P}_{not}^g and $\hat{\delta}_k$.

4.3 Solution procedure

As mentioned at the beginning of this section, a two-phase approach is proposed to solve the planning model. The flowchart of the optimisation procedure is shown in Fig. 2.

The detailed description of the proposed algorithm is given as follows:

- (1) *Initialisation*: Set a small value ϵ to control the convergence and initiate the iteration counter $\nu = 0$.
- (2) *Phase one master problem solution*: Solve the master problem considering only the normal operating states. Note that for the first iteration, the master problem is solved without considering any Benders cut, e.g. constraint (36).




Fig. 2 Flowchart of the solution approach

(3) *Relaxed subproblem solution*: With P_{n0r}^g and δ_k^g obtained from the master problem, solve the subproblem as an LP by relaxing the flow direction variable y_{kct} as a continuous variable in $[0, 1]$.

(4) *Convergence check*: If $|Z_{up}^{(\nu)} - Z_{down}^{(\nu)}| / |Z_{down}^{(\nu)}| \leq \epsilon$, the optimal solution for the relaxed original problem is achieved and proceed to phase two. Otherwise, generate Benders cut and go to step (2). Set $\nu \leftarrow \nu + 1$.

(5) *Phase two master problem solution*: Solve the master problem while keeping all the Benders cut generated from phase one.

(6) *Unrelaxed subproblem solution*: Enforce the binary constraint for the flow direction y_{kct} . Solve the unrelaxed subproblem into optimality and output the optimal solution \hat{y}_{kct} .

(7) *Sensitivities generation*: Fix $y_{kct} = \hat{y}_{kct}$. Solve the subproblem and obtain the dual variables associated with constraints (40) and (41).

(8) *Convergence check*: If $|Z_{up}^{(\nu)} - Z_{down}^{(\nu)}| / |Z_{down}^{(\nu)}| \leq \epsilon$, the optimal solution is obtained. Otherwise, generate Benders cut and go to step (5). Set $\nu \leftarrow \nu + 1$.

The two-phase approach is an efficient method to accelerate convergence of Benders decomposition [32]. In phase one, we solve the master problem with the relaxed subproblem at optimality. All the Benders cuts generated in phase one are valid for the original problem. The reason is that the relaxed subproblem provides a lower bound on the original subproblem so that it will also generate a valid lower bound for α [33]. In addition, the objective value obtained from phase one provides a lower bound for the original problem, which can be used to evaluate the quality of the final solution. In phase two, the generation of the Benders cut is heuristic because it involves fixing the binary variable y_{kct} .

Although it cannot ensure a global optimum, our case studies show that the solution obtained is very close to the lower bound of the original problem. Therefore, the solution is of high quality from an engineering point of view.

5 Numerical case studies

The IEEE 118-bus and the Polish 2383-bus system are selected to test the effectiveness of our planning model and the solution approach. The system data is provided in the MATPOWER package [34]. There is only one load pattern defined for these standard systems. For the IEEE 118-bus system, we treat the given loads as the normal load levels. The peak loads are 1.2 times the given loads and the lower loads are 80% of the given loads. For the Polish system, the provided load data in [34] is the winter peak so we treat the normal loads and low loads as 80 and 60% of the given loads, respectively. All simulations are performed on a personal laptop with an Inter Core(TM) i5-2400M CPU @ 2.30 GHz and 4.00 GB of RAM. The problem is modelled by using the MATLAB toolbox YALMIP [35] with CPLEX [36] as the solver.

In this study, we investigate the allocation strategy for one typical VSR: TCSC. The allowable compensation range of TCSC varies from -70 to $+20\%$ of the corresponding line reactance [37]. Thus, the physical limits for b_k^V are $-(1/6x_k) \leq b_k^V \leq (7/3x_k)$. The value of M_k in (13) and (14) is selected as $|(7/3x_k)\theta_k^{\max}|$. The investment cost of the TCSC depends on its lifespan and capacity rating. The annual investment cost A_1 is converted from the total investment cost by using the interest rate and life span of the TCSC [9, 25]. The interest rate is selected to be 5% and the life span of the TCSC is 5 years [37].

5.1 IEEE 118-bus system

The IEEE-118 bus system has 118 buses, 19 generators, 177 transmission lines and nine transformers. The total load at the peak level is 4930 MW and the generation capacity is 6466 MW. The thermal flow limits are decreased artificially to create congestion. In practice, it is unnecessary to consider every transmission line as candidate location to install FACTS device due to some physical or economic limitations. Hence, we first perform a preliminary simulation based on the sensitivity approach proposed in [14] to obtain 30 TCSC candidate locations. In addition, based on the congestion severity [38], we consider 30 contingencies in the planning model so the number of operating states in this test case is 93.

Table 1 provides a comparison of the non-decomposed approach, the MBD approach and proposed Benders algorithm. The non-decomposed model indicates solving the complete model in Section 3 directly [27]. For such a large optimisation problem, it may take excessive time to get a solution within the default mipgap (0.01%) in CPLEX. For the sake of comparison, we simply seek a solution within a given computation time. As shown in the table, the total planning cost for the non-decomposed model is \$1099.59 M with a mipgap 1.47% after 3 h. In addition, two TCSCs are selected to be installed in the system. The results for the MBD approach show that five TCSCs should be installed in the system and the total planning cost is \$1090.03 M. The computation time decreases significantly using MBD, requiring only 315.86 s. The proposed Benders algorithm suggests to install six TCSCs in the system and the total planning cost is \$1088.21 M. The lower bound from phase one for this test system is \$1087.20 M, indicating that the solution obtained by the proposed approach is close enough to the global optimal solution. The required computational time is 244.81 s. As compared with MBD, the total planning cost is decreased by 0.20% and the computational time is reduced by 22.22%.

Fig. 3 shows hourly generation cost for each operating state under the peak and normal load level. The generation cost reduction can be observed for all the operating states by installing TCSCs into the network. The hourly generation cost for the base case during the peak load level is \$167,653 per hour without any TCSC. This cost decreases to \$156,907 per hour with the installation of six TCSCs. The cost reduction is mainly due to the




Fig. 3 Hourly generation cost for peak and normal load level




Fig. 4 Generation rescheduling under different contingencies for the peak load level




Fig. 5 Load shedding under different contingencies for peak load level

congestion relief which enables more power to be delivered from cheaper generators. It can also be seen that the generation cost reduction at the normal load level is not as much as that in the peak load level for all the operating states except for contingency (25–27).

Fig. 4 shows generation rescheduling under different contingencies for the peak load level. Fig. 5 gives the load shedding at the peak load level for the five contingencies which involve load shedding. Note that there is no involuntary load shedding for the operating states under normal and low load level. From Fig. 4, it can be seen that the amount of generation rescheduling decreases for the majority of operating states. The largest reduction occurs under contingency (8–5) where the amount of generation rescheduling decreases from 1200 MW to about 600 MW. Under contingency (25–27), the rescheduling amount increases by about 300 MW with TCSC. However, about 60 MW load shedding can be avoided in that contingency as shown in Fig. 5. This indicates that the installation of TCSC enable cheaper ways, such as, rescheduling, to reduce load shedding. As can be seen in Fig. 5, the load shedding for contingency (30–17), (38–37), (26–30) and (25–27) are eliminated with TCSC. For the most severe contingency (8–5), the load shedding decreases from 76.36 to 15.30 MW.

Table 2 compares the annual cost for the case with and without TCSC. We categorise the cost into four groups: (i) generation cost, (ii) generation rescheduling cost, (iii) load shedding cost and (iv) investment in TCSC. Except for the investment in TCSC, it can be seen that cost decreases in all the other categories with the installation of TCSCs. The annual reduction for the total planning

Table 1 Comparison of the investment results for IEEE 118-bus system

Approach	Non-decomposed [27]	MBD [31]	Proposed BD
TCSC locations (i – j)	(26–30), (30–38)	(17–31), (20–21), (26–30), (22–23), (30–38)	(17–31), (20–21), (21–22), (26–30), (22–23), (30–38)
Investment, million \$	1.64	2.68	2.94
total cost, million \$	1099.59	1090.03	1088.21
CPU time	3.00 h	315.86 s	244.81 s

Table 2 Annual cost with and without TCSC for IEEE 118-bus system

Cost category	Annual cost, million \$	
	w/o TCSC	w/t TCSC
generation cost in normal state	1048.31	1018.74
generation cost in contingency	66.58	65.30
rescheduling cost	1.09	0.54
load shedding cost	8.81	0.70
investment in TCSC	—	2.94
total cost	1124.79	1088.21




Fig. 6 Evolution of the proposed Benders algorithm for IEEE 118-bus system

cost is about \$36.58 M, which approximately accounts for 3.25% of the annual planning cost.

Fig. 6 depicts the convergence on the IEEE 118-bus system. In the first three iterations, the penalty terms in (37) are not zero so the objective value of subproblem is very large. We decrease the range of y-axis to improve the readability of the figure. As can be observed from the figure, it takes five iterations for the problem in phase one to converge. After that, only one iteration is needed for the problem in phase two to converge.

5.2 Polish system

The Polish system includes 2383 buses, 327 generators, 2728 transmission lines and 168 transformers. The total load at the peak level is 20,465 MW and the generation capacity is 29,594 MW. Based on sensitivity method, we select 50 candidate locations to install TCSC. We consider 60 contingencies so the number of operating states for this test system is 183.

Table 3 gives a comparison of the MBD approach and the proposed algorithm. The non-decomposed approach [27] is not included in the table since the CPLEX solver gives no solution after 5 h on this system. The convergence tolerance ϵ is selected to be 0.35%. In addition, a time limit of 3 h is set for each algorithm. At the end of each iteration, if the summation of the computational time for master problem and sub-problem exceeds 3 h, the

Table 3 Comparison of the investment results for polish system

Approach	MBD [31]	Proposed BD
TCSC locations ($i - j$)	(1507–1303), (123–111) (432–356), (920–821) (7–4), (1181–1190) (1467–834), (10–5) (612–413), (114–131) (578–366), (1489–1431) (29–7)	(29–13), (7–4), (10–3) (1342–1301), (1948–1649) (432–356), (920–821) (395–334), (493–306) (11–4), (152–66) (612–413), (1489–1431) (833–1230), (1055–1079)
Investment, million \$	12.34	12.43
total cost, million \$	10,796.54	10,778.41
CPU time, h	3.13	1.50

Table 4 Annual cost with and without TCSC for the polish 2383-bus system

Cost category	Annual cost, million \$	
	w/o TCSC	w/t TCSC
generation cost in normal state	9527.18	9464.42
generation cost in contingency	1299.87	1291.18
rescheduling cost	6.28	4.83
load shedding cost	9.59	5.55
investment in TCSC	—	12.43
total cost	10,842.93	10,778.41




Fig. 7 Evolution of the proposed Benders algorithm for Polish system

algorithm will terminate. As can be seen from the table, the MBD suggests to install 13 TCSCs and the total planning cost is \$10,796.54 M. Moreover, it takes 3.13 h for the MBD to achieve a gap of 1.12%. Fifteen TCSCs are selected to be installed in the system by using the proposed algorithm. The planning cost is \$10,778.41 M and the computational time is decreased to 1.5 h. The proposed algorithm demonstrates better performance in relieving the computational burden when applied to practical large-scale system as compared with MBD.

Table 4 shows the comparison of the planning cost for the case with and without TCSC. The annual savings for the Polish system is about \$64.5 M.

Fig. 7 illustrates the iteration process of the proposed Benders algorithm. It can be seen that after five iterations, the problem in phase one converges to the lower bound of \$10,774.27 M. Then it takes another five iterations for the problem in phase two to converge.

5.3 Discussion

The proposed approach shows better performance than the MBD in determining the optimal locations of TCSC. Although the difference of the total planning cost between these two approaches is not significant, the computational time is greatly reduced by using the proposed approach, especially for the practical large-

scale system. Another advantage of the proposed approach is that it can provide a lower bound for the complete planning model, i.e. the objective value of phase one. This information can be leveraged to evaluate the quality of the obtained solution.

The focus of this paper is to determine the optimal locations of series FACTS devices based on cost. The obtained solution provides a good trade-off between FACTS investment cost and system operation cost. Note that the proposed planning model adopts a DC power flow, which ignores power loss and reactive power. Thus, the proposed model is suitable for preparatory power network design. For more detailed security analysis, the obtained results can be analysed by using an AC power flow model. In that analysis, the power losses and various security indices [39] can be computed and analysed.

6 Conclusion

This paper proposes a planning model to allocate VSR considering different operating conditions and critical $N - 1$ contingencies. The original planning model is a large-scale MINLP model. A reformulation is introduced to transform the MINLP model into an MILP model. To further reduce the computation burden, a two-phase Benders decomposition is proposed. The solution obtained is not guaranteed to be a global optimum but analysis indicates the solution is near optimal. Case studies on the IEEE 118-bus and the Polish system demonstrate the performance of the proposed algorithm. The simulation results show that the generation cost for both the normal operating states and contingency states can be reduced with the installation of VSR. In addition, the cost reductions can be observed in the generation rescheduling and involuntary load shedding following contingencies.

8 Acknowledgments

This work was supported in part by ARPae (Advanced Research Projects Agency Energy), and in part by the Engineering Research Center Program of the National Science Foundation and the Department of Energy under NSF Award Number EEC-1041877 and the CURENT Industry Partnership Program.

9 References

- [1] Stoft, S.: 'Power system economics: designing market for electricity' (Wiley-IEEE Press, New York, NY, USA, 2002)
- [2] Hingorani, N.G., Gyugyi, L.: 'Understanding FACTS: concept and technology of flexible AC transmission system' (Wiley-IEEE Press, New York, NY, USA, 1999)
- [3] Lie, T.T., Deng, W.: 'Optimal flexible AC transmission systems (FACTS) devices allocation', *Electr. Power Energy Syst.*, 1997, **19**, (2), pp. 125–134
- [4] Zhang, X., Rehtanz, C., Pal, B.: 'Flexible AC transmission systems: modelling and control' (Springer, Berlin, Germany, 1999)
- [5] 'Green Electricity Network Integration'. Available at <http://arpa-e.energy.gov/?q=arpa-e-programs/geni>, accessed 10 May 2016
- [6] Dimitrovski, A., Li, Z., Ozpineci, B.: 'Magnetic amplifier-based power flow controller', *IEEE Trans. Power Deliv.*, 2015, **30**, (4), pp. 1708–1714
- [7] Jirapong, P., Ongsakul, W.: 'Optimal placement of multi-type FACTS devices for total transfer capability enhancement using hybrid evolutionary algorithm', *Electr. Power Compon. Syst.*, 2007, **35**, (9), pp. 981–1005
- [8] Yorino, N., El-Araby, E.E., Sasaki, H., et al.: 'A new formulation for FACTS allocation for security enhancement against voltage collapse', *IEEE Trans. Power Syst.*, 2003, **18**, (1), pp. 3–10
- [9] Cai, L.J., Erlich, I., Stamtis, G.: 'Optimal choice and allocation of FACTS devices in deregulated electricity market using genetic algorithms'. Proc. IEEE PES Power Syst. Conf. Exposition, New York, USA, October 2004, pp. 201–207
- [10] Gerbex, S., Cherkaoui, R., Germond, A.J.: 'Optimal location of multi-type FACTS devices in a power system by means of genetic algorithm', *IEEE Trans. Power Syst.*, 2001, **16**, (3), pp. 537–543
- [11] Ghahremani, E., Kamwa, I.: 'Optimal placement of multiple-type FACTS devices to maximize power system loadability using a generic graphical user interface', *IEEE Trans. Power Syst.*, 2013, **28**, (2), pp. 764–778
- [12] Saravanan, M., Slochanal, S.M.R., Venkatesh, R., et al.: 'Application of PSO technique for optimal location of FACTS devices considering system loadability and cost of installation', *Electric. Power Syst. Res.*, 2007, **77**, (3), pp. 276–283
- [13] Baghaee, H.R., Mirsalim, M., Gharehpetian, G.B., et al.: 'Security/cost-based optimal allocation of multi-type FACTS devices using multi-objective particle swarm optimization', *Simulation*, 2012, **88**, (8), pp. 999–1010
- [14] Orfanogianni, T., Bacher, R.: 'Steady-state optimization in power systems with series FACTS devices', *IEEE Trans. Power Syst.*, 2003, **18**, (1), pp. 19–26

- [15] Acharya, N., Mithulananthan, N.: 'Locating series FACTS devices for congestion management in deregulated electricity markets', *Electric. Power Syst. Res.*, 2007, **77**, (3), pp. 352–360
- [16] Yang, G., Hovland, G., Majumder, R., *et al.*: 'TCSC allocation based on line flow based equations via mixed-integer programming', *IEEE Trans. Power Syst.*, 2007, **22**, (4), pp. 2262–2269
- [17] Baran, M.E., Wu, F.F.: 'Optimal sizing of capacitors placed on a radial distribution system', *IEEE Trans. Power Deliv.*, 1989, **4**, (1), pp. 735–743
- [18] Ziaee, O., Choobineh, F.: 'Optimal location-allocation of TCSCs and transmission switch placement under high penetration of wind power', *IEEE Trans. Power Syst.*, 2017, **32**, (4), pp. 3006–3014
- [19] Wibowo, R.S., Fathurodli, T.P., Penangsang, O., *et al.*: 'Security constrained optimal power flow with facts devices using bender decomposition'. Proc. TENCON 2014-2014 IEEE Region 10 Conf., Bangkok, Thailand, October 2014, pp. 1–5
- [20] Mohammadi, J., Hug, G., Kar, S.: 'A benders decomposition approach to corrective security constrained OPF with power flow control devices'. Proc. IEEE PES General Meeting, Vancouver, BC, Canada, July 2013, pp. 1–6
- [21] Ardakani, M.S., Hedman, K.W.: 'A fast LP approach for enhanced utilization of variable impedance based FACTS devices', *IEEE Trans. Power Syst.*, 2016, **31**, (3), pp. 2204–2213
- [22] Ding, T., Bo, R., Li, F., *et al.*: 'Optimal power flow with the consideration of flexible transmission line impedance', *IEEE Trans. Power Syst.*, 2016, **31**, (2), pp. 1655–1656
- [23] Miñano, R.Z., Conejo, A.J., Milano, F.: 'OPF-based security redispatching including FACTS devices', *IET Gener. Transm. Distrib.*, 2008, **2**, (6), pp. 821–833
- [24] Elmitwally, A., Eladl, A., Morrow, J.: 'Long-term economic model for allocation of FACTS devices in restructured power systems integrating wind generation', *IET Gener. Transm. Distrib.*, 2016, **10**, (1), pp. 19–30
- [25] Wibowo, R.S., Yorino, N., Eghbal, M., *et al.*: 'FACTS devices allocation with control coordination considering congestion relief and voltage stability', *IEEE Trans. Power Syst.*, 2011, **26**, (4), pp. 2302–2310
- [26] Zhang, X., Tomsovic, K., Dimitrovski, A.: 'Security constrained multi-stage transmission expansion planning considering a continuously variable series reactor', *IEEE Trans. Power Syst.*, 2017, **32**, (6), pp. 4442–4450
- [27] Zhang, X., Tomsovic, K., Dimitrovski, A.: 'Optimal investment on series FACTS device considering contingencies'. Proc. North American Power Symp., Denver, CO, USA, September 2016, pp. 1–6
- [28] Adams, W.P., Forrester, R.J.: 'Linear forms of nonlinear expressions: new insights on old ideas', *Oper. Res. Lett.*, 2007, **35**, (4), pp. 510–518
- [29] Zhang, H., Vittal, V., Heydt, G.T., *et al.*: 'A mixed-integer linear programming approach for multi-stage security-constrained transmission expansion planning', *IEEE Trans. Power Syst.*, 2012, **27**, (2), pp. 1125–1133
- [30] Conejo, A.J., Castillo, E., Minguéz, R., *et al.*: 'Decomposition techniques in mathematical programming: engineering and science applications' (Springer Science & Business Media, Heidelberg, Germany, 2006)
- [31] Hu, B., Wu, L.: 'Robust SCUC considering continuous/discrete uncertainties and quick-start units: a two-stage robust optimization with mixed integer recourse', *IEEE Trans. Power Syst.*, 2016, **31**, (2), pp. 1407–1419
- [32] Papadakos, N.: 'Integrated airline scheduling', *Comp. Oper. Res.*, 2009, **36**, (1), pp. 176–195
- [33] Zheng, Q.P., Wang, J., Pardalos, P.M., *et al.*: 'A decomposition approach to the two-stage stochastic unit commitment problem', *Ann. Oper. Res.*, 2013, **210**, (1), pp. 387–410
- [34] Zimmerman, R.D., Murillo-Sanchez, C.E., Thomas, R.J.: 'MATPOWER: steady-state operations, planning and analysis tools for power system research and education', *IEEE Trans. Power Syst.*, 2011, **26**, (1), pp. 12–19
- [35] Löfberg, J.: 'YALMIP: A toolbox for modeling and optimization in MATLAB'. Proc. CACSD Conf., Taipei, Taiwan, July 2004, pp. 284–289
- [36] 'IBM CPLEX'. Available at <http://www-01.ibm.com/software/commerce/optimization/cplex-optimizer/index.html>, accessed 7 May 2016
- [37] Tiwari, P.K., Sood, Y.R.: 'An efficient approach for optimal allocation and parameters determination of TCSC with investment cost recovery under competitive power market', *IEEE Trans. Power Syst.*, 2013, **28**, (3), pp. 2475–2484
- [38] Ejebe, G., Wollenberg, B.: 'Automatic contingency selection', *IEEE Trans. Power App. Syst.*, 1979, **PAS-98**, (1), pp. 97–109
- [39] Baghaee, H.R., Abedi, M.: 'Calculation of weighting factors of static security indices used in contingency ranking of power systems based on fuzzy logic and analytical hierarchy process', *Int. J. Electr. Power Energy Syst.*, 2011, **33**, (4), pp. 855–860